ENGINEERING TOMORROW



**Data Sheet** 

# Trouble shooting - Liquid level sensors Type **AKS 4100** and **AKS 4100U**

Designed specifically to measure liquid levels in a wide range of refrigeration applications



The AKS 4100/4100U liquid level sensor is designed specifically to measure liquid levels in a wide range of refrigeration applications.

The AKS 4100/4100U liquid level sensor is based on a proven techhology called Time Domain Reflectometry (TDR) or Guided Micro Wave.

AKS 4100/4100U liquid level sensor can be used to measure the liquid level of many different refrigerants in vessels, accumulators, receivers, standpipes, etc.

The electrical output is a 2-wired, loop powered 4–20 mA output signal, which is proportional to the refrigerant liquid level.





# **Product specification**

# **Compatibility**

## **Product identification**

Figure 1: Product identification



From the gray label the readings listed below must be noted.

These are used for on-site identification of hardware/software compatibility and for dialog with Danfoss:

#### Figure 2: Gray label

1. Code number	Danfots Made in France www.Danfoss.com Liquid Level Sensor: AKS 4100 084H4501 S/N: F130000000183560 Manufacturing date: 29-NOV-2013 Input voltage: 1430V DC	C
----------------	--	---

## HMI display readings

Figure 3: Display after power on



The label readings above together with the software stated configuration will identify any possible compatibility problem between the HMI and the converter.

To manually get the software versions of the converter, sensor and HMI please follow the steps on page 2.



#### Versions

#### Path to software versions

Please follow the commands to the right to get to the Information menus 2.1.2, 2.1.3 and 2.1.4 and note the versions.

#### Figure 4: Information menu



Figure 5: Note the versions

VX . XX . XX	CONV. (Converter)	Menu 2.1.2
VX . XX . XX	SENSOR	Menu 2.1.3
VX . XX . XX	HMI	Menu 2.1.4

## Factory software combinations

To the right is the list of the original paired software versions. These combinations are fully functional.



#### Trouble shooting - Liquid level sensors, type AKS 4100 and AKS 4100U

#### Table 1: Software versions

Manufacturing date Product label	HMI Menu 2.1.4	Converter Menu 2.1.2
31-Oct-11	1.06	1.04
20-Feb-12	1.07	1.06.01
14-May-12	1.08	1.06.01
29-May-12	1.08	1.07.01A
27-Sep-12	1.09	1.07.02
17-Sep-13	1.1	1.08.01

# Software backwards compatibility

If, for some reason, the HMI or the converter has been replaced, other version combinations could have been introduced.

Between the different software versions there is to some extend backwards compatibility.

Below table includes green boxes for the allowed version combinations and red boxes for the not allowed combinations.





### • NOTE:

To avoid any problem derived from non compatible software versions it is very important to verify compatibility in the table. In case of any conflict between the two versions Danfoss recommends to replace the HMI display to an allowed software version.



# **Mechanical**

# Cable version

#### Figure 6: Cable version



The cable version is sensitive to variations of the surrounding geometry and materials.

Essential is to avoid these situations:

- Variations in standpipe diameter. In such cases Danfoss recommend the coaxial version.
- Cable not straightening out (missing or hanging counterweight) or cable touching intruding parts/tubing.
- Standpipe made of non-metallic material. Danfoss recommend the coaxial version.

If you are not sure whether the geometry is regular, Danfoss recommend the use of the coaxial version.

# Mechanical assembly

#### Figure 7: Mechanical assembly



It is important to keep the cavity in the upper cable connector dry and clean at all time prior to assembly. For this purpose the packaging includes a red cap to cover the top part.

To secure the correct assembly of the converter and cable connector a vertical press to the converter is needed. A mechanical stop indicates the right vertical position.

Remember to tighten the Allen key set bolt with 10 Nm during press down.



# **Electrical**

# Electrical requirements (Power supply voltage)

#### Figure 8: Power supply voltage

	Connector for HMI
1. V DC	
2. VAC	

**1.V DC** Set the Voltmeter to DC Voltage

2. VAC Switch the Voltmeter to AC Voltage

The Signal converter requires a stable and pure DC power supply.

To check the power quality connect a voltmeter + and - terminals to the + and - terminals of the converter (+ to +, - to -) and keep this wiring throughout below testing.

Set the Voltmeter to DC Voltage. The DC readings must be in the range of 14–30 V.

Switch the Voltmeter to AC Voltage. The AC readings must be lower than 5 V.

If AC readings are above 5 V, the power supply does not meet the required quality.

## Signal current

Depending on the wiring between the AKS 4100 and the controller - PLC or EKC/EKE 347 - the signal current can vary.

It is important to have sufficient and identified current to the controller. Below is the path to a controlled forced mA output from the AKS 4100.

Just follow below commands and compare the readings of the forced mA output with the readings in the controller. Remember to measure all current output possibilities of the AKS 4100. These are: 3.5, 4, 6, 8, 10, 12, 14, 16, 18, 20 and 22 mA.

If connected to EKC 347 controller: Read the parameter u30 in EKC for comparison of the forced mA output of the AKS 4100.

If connected to PLC controller: Ask local operator how to read incoming current and compare.

#### **O** NOTE:

Not all controllers allow a current signal below 4 mA from the AKS 4100. A configured lowest signal of 3.5 mA will in these cases often result in an error reading on the controller.



#### Figure 9: How to force mA output



## System fault location

#### Table 3: System fault location

Symptom	Possible cause	Action
<ul> <li>Rebooting</li> <li>Not possible to access the setup menu</li> <li>Crash or reboot after accessing the setup menu</li> <li>Showing "Starting up" continuously</li> <li>Configurations are not saved</li> </ul>	a) Incompatible software versions in HMI and con- verter respectively. See table on page 2	Identify potential conflict between softwares as de- scribed on pages 1 and 2. If not possible to get to Information menu (2.1.2 to 2.1.4) identify the converter from the label and test a HMI which for sure is compatible.
<b>No reaction/ Frozen level</b> Device stays on level ~ 80%, seems "frozen"	a) Non-regular geometry of the standpipe (see page 3) b )Standpipe dimensions out of specification (see Danfoss installation guide) c) Manufacturing date before Sept. 2013	Increase the parameter blocking distance or detec- tion delay up to the level frozen value (see Danfoss in- stallation guide). The value of the blocking distance/ detection delay must be outside the measuring range. If the values of blocking distance/ detection delay cannot be increased further replace the AKS 4100 to a coaxial type (if cable type) or an AKS 4100 (any type) produced after Sep. 2013.
Black-/ interrupted display After HMI connection - no display No access to con- verter setup.	a) Interrupted cable wiring between HMI and con- verter.	Check the flat cable and connector. Replace the HMI according to compatibility table on page 2.
Unstable/ wrong measurements Periodic fluctuating measurements.	<ul><li>a) Incompatible softwares between HMI and converter.</li><li>b) Inductor problem on early versions.</li></ul>	Check the compatibility according to table on page 2. Replace with the latest HMI version.
<b>Moisture in display</b> Water leaking through glass sealing.	a) Early versions less water resistant.	Replace with the latest HMI version.
<b>Smell of NH<sub>3</sub></b> Leakage inside-out of Ammonia Display window discolored/ lost transparency	a) Weak sealings in some early versions.	HMI <sup>(1)</sup> : Replace the HMI with a new version Mechanical process connection: Date code before February 2013: Replace the mechanical process connection with a new version. Date code after February 2013: No need to replace the mechanical process connec- tion



<sup>(1)</sup> Please note!

- HMI replaced after March 16, 2014 and marked externally with an "A"
- Mechanical process connection replaced after February 2013 and marked with a date code.

A small amount of ammonia may still be smelled when HMI is dismounted. This represent no safety risk.

All components are well protected and the AKS 4100/4100U continues to measure and send the 4–20 mA signal corresponding to the liquid level.



# Prior to contacting Danfoss; please collect these data:

## Collect these data:

#### Figure 10: Data Form

Γ	Code number			
Data from the grey product	Serial number			
	Manufacturing date			
	Software versions	Converter (2.1.2) Sensor (2.1.3) HMI (2.1.4)		
	Probe length (2.3.4)			
	Blocking distance (2.3.2)			
Data from	4 mA (2.4.3) =		mm	
HMI menu	20 mA (2.4.4) =		mm	
	Coaxial or Cable			
	Refrigerant			
	Refrigerant temperature			
	Refrigerant pressure			



## Certificates, declarations, and approvals

## Mandatory: Intro to Certificates, declarations, and approvals

The list contains all certificates, declarations, and approvals for this product type. Individual code number may have some or all of these approvals, and certain local approvals may not appear on the list.

Some approvals may change over time. You can check the most current status at danfoss.com or contact your local Danfoss representative if you have any questions.

# Valid approvals

#### Table 4: Valid approvals

File name	Document type	Document topic	Approval authority
GOST FR.C.29.004.A 51938	Measuring - Performance Certificate		
UA.10146.D.00075-19	UA Declaration	EMCD/LVD	LLC CDC EURO-TYSK
033F0689.AA	EU Declaration	EMC	Danfoss
MD 033F0686.AH	Manufacturers Declaration	PED	Danfoss
033F0695.AA	Manufacturers Declaration	China RoHS	Danfoss
0F18749.513467890YTN	Pressure - Safety Certificate	CRN	TSSA
0F19272.2	Pressure - Safety Certificate	CRN	TSSA

#### Table 5: Approvals and certification

CE	This device fufills the statutory requirements of the EMC directives. The manufacturer certifies successful test- ing of the product by applying the CE mark.
C	Valid for AKS 4100 - <b>Not valid for AKS 4100U:</b> Pattern Approval Certificate of Measuring Instruments for the Russian Federation
EAC	Valid for AKS 4100 - <b>Not valid for AKS 4100U:</b> In compliance with EMC regulations in the Russian Federation
EMC	EMC Directives 2004 / 108 / EC and 93 / 68 / EEC in conjunction with EN 61326-1 (2006) and EN 61326-2-3 (2006). The device conforms to these standards if: - the device has a coaxial probe or - the device has a single probe that is installed in a metallic tank
LVD	Low-Voltage Directives 2006 / 95 / EC and 93 / 68 / EEC in conjunction with EN 61010-1 (2001)
NAMUR	NAMUR NE 21 Electromagnetic Compatibility (EMC) of Industrial Process and Laboratory Control Equipment
	NAMUR NE 43 Standardization of the Signal Level for the Failure Information of Digital Transmitters

# **Online support**

Danfoss offers a wide range of support along with our products, including digital product information, software, mobile apps, and expert guidance. See the possibilities below.

#### **The Danfoss Product Store**



The Danfoss Product Store is your one-stop shop for everything product related—no matter where you are in the world or what area of the cooling industry you work in. Get quick access to essential information like product specs, code numbers, technical documentation, certifications, accessories, and more.

Start browsing at store.danfoss.com.

#### Find technical documentation



Find the technical documentation you need to get your project up and running. Get direct access to our official collection of data sheets, certificates and declarations, manuals and guides, 3D models and drawings, case stories, brochures, and much more.

Start searching now at www.danfoss.com/en/service-and-support/documentation.

#### **Danfoss Learning**



Danfoss Learning is a free online learning platform. It features courses and materials specifically designed to help engineers, installers, service technicians, and wholesalers better understand the products, applications, industry topics, and trends that will help you do your job better.

Create your Danfoss Learning account for free at www.danfoss.com/en/service-and-support/learning.

#### Get local information and support



Local Danfoss websites are the main sources for help and information about our company and products. Find product availability, get the latest regional news, or connect with a nearby expert—all in your own language.

Find your local Danfoss website here: www.danfoss.com/en/choose-region.

#### **Spare Parts**



Get access to the Danfoss spare parts and service kit catalog right from your smartphone. The app contains a wide range of components for air conditioning and refrigeration applications, such as valves, strainers, pressure switches, and sensors.

Download the Spare Parts app for free at www.danfoss.com/en/service-and-support/downloads.

#### Coolselector<sup>®</sup>2 - find the best components for you HVAC/R system



Coolselector<sup>®</sup>2 makes it easy for engineers, consultants, and designers to find and order the best components for refrigeration and air conditioning systems. Run calculations based on your operating conditions and then choose the best setup for your system design.

Download Coolselector<sup>®</sup>2 for free at coolselector.danfoss.com.

**Danfoss A/S** Climate Solutions • danfoss.com • +45 7488 2222

Any information, including, but not limited to information on selection of product, its application or use, product design, weight, dimensions, capacity or any other technical data in product manuals, catalogues descriptions, advertisements, etc. and whether made available in writing, orally, electronically, online or via download, shall be considered informative, and is only binding if and to the extent, explicit reference is made in a quotation or order confirmation. Danfoss cannot accept any responsibility for possible errors in catalogues, brochures, videos and other material. Danfoss reserves the right to alter its products without notice. This also applies to products ordered but not delivered provided that such alterations can be made without changes to form, fit or function of the product. All trademarks in this material are property of Danfoss A/S or Danfoss group companies. Danfoss and the Danfoss logo are trademarks of Danfoss A/S. All rights reserved.

Danfoss

ENGINEERING TOMORROW