



This certifies that

DANFOSS A/S

has had the undermentioned product examined, tested and found, when correctly installed, to comply with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations and Scottish Water Byelaws.

EV220W 32B NO G 114 BSP(F), EV220W 40B NO G 112 BSP(F) & EV220W 50B NO G 2 BSP(F) SOLENOID VALVES

The certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Directory (www.wras.co.uk/directory)

The product so mentioned will be valid until the end of:

April 2024

1904025

Certificate No.

A handwritten signature in black ink that reads 'J Funnell'.

Secretary

A handwritten signature in black ink, consisting of several vertical strokes followed by a horizontal line.

Chairman, Product Assessment Group

APPROVAL INFORMATION

Validity dates:	This approval is valid for fittings (as listed below in model) manufactured AND installed between April 2019 & April 2024
Section Number:	2230
Section title:	VALVES - SOLENOID, METAL.
Installation requirement notes:	R001 (IRN's are set out in Appendix A)
Product description:	Normally open solenoid valve with brass body and EPDM diaphragms and seats. The inlet incorporates a stainless steel strainer. Maximum working pressure 10.0 bar. Maximum operating temperature 50°C.
Size:	See model
Identification Marking:	Danfoss on body
Manufacturer:	Danfoss A/S, Industrial Automation
Factor:	Danfoss A/S
Model:	EV220W 32B NO G 114 BSP(F) Models added July 2019: EV220W 40B NO G 112 BSP(F) & EV220W 50B NO G 2 BSP(F)

APPENDIX A

INSTALLATION REQUIREMENTS & NOTES

You are advised to draw customers' attention to the installation requirements and notes set out below which must be followed to ensure that the fittings described above are installed in accordance with the requirements of the Regulations and Byelaws:

IRN R001

See text of entry for Installation Requirements or Notes.