



This certifies that

DANFOSS A/S

has had the undermentioned product examined, tested and found, when correctly installed, to comply with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations and Scottish Water Byelaws.

**"EV250BW 10B G 38 NC, EV250BW 12B G 12 NC
EV250BW 18B G 34 NC & EV250BW 22B G 1 NC SOLENOID VALVES "**

The certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Directory (www.wras.co.uk/directory)

The product so mentioned will be valid until the end of:

March 2025

2003353

Certificate No.

A handwritten signature in black ink, appearing to read 'J Funnell', written in a cursive style.

Secretary

A handwritten signature in black ink, consisting of several vertical strokes followed by a horizontal line, written in a cursive style.

Chairman, Product Assessment Group

APPROVAL INFORMATION

Validity dates: This approval is valid for fittings (as listed below in model) manufactured AND installed between March 2020 & March 2025

Section Number: **2230**

Section title: **VALVES - SOLENOID, METAL.**

Installation requirement notes: **R001**
(IRN's are set out in Appendix A)

Product description: Range of normally closed solenoid valves with brass bodies, EPDM diaphragms & 'O'-rings.

Maximum working pressure 10.0 bar. Maximum operating temperature 90°C.

Size: 3/8" BSP (F), 3/4" BSP (F) & 1" BSP (F).

Identification Marking: Flow arrow on body. Danfoss logo & technical information on operating member.

Manufacturer: Danfoss A/S, Industrial Automation

Factor: Danfoss A/S

Model: EV250BW 10B G 38 NC
EV250BW 12B G 12 NC
EV250BW 18B G 34 NC
EV250BW 22B G 1 NC

APPENDIX A

INSTALLATION REQUIREMENTS & NOTES

You are advised to draw customers' attention to the installation requirements and notes set out below which must be followed to ensure that the fittings described above are installed in accordance with the requirements of the Regulations and Byelaws:

IRN R001

See text of entry for Installation Requirements or Notes.