

Danfoss A/S6430 Nordborg
Denmark
CVR nr.: 20 16 57 15Telephone: +45 7488 2222
Fax: +45 7449 0949**MANUFACTURER'S DECLARATION****Danfoss A/S****Floor Heating and Electronic Controls**


declares under our sole responsibility that the

Product category: Manifold

Type designation(s): SSM-F (Stainless steel manifold with flow meters)

Covered by this declaration is in conformity with the following directive(s), standard(s) or other normative document(s), provided that the product is used in accordance with our instructions.

- PEX pipes in compliance with ISO15875 and PERT pipes in compliance with ISO 22391 in the following dimensions:
 - 12 x 2 mm, 13 x 2 mm, 14 x 2 mm, 15 x 2,5 mm, 16 x 1,5 mm, 16 x 2 mm, 16 x 2,2 mm, 17 x 2 mm, 18 x 2 mm, 18 x 2,5 mm, 20 x 2 mm, 20 x 2,25 mm and 20 x 2,5 mm.
- Can be used with the following SSM-F manifolds:
 - 088U0752, 088U0753, 088U0754, 088U0755, 088U0756, 088U0757, 088U0758, 088U0759, 088U0760, 088U0761, 088U0762, on the condition that appropriate fittings are used.

Date: 2020.10.07 Place of issue: Vejle, DK	Issued by  Signature: Name: Peter Skov Kjeldsteen Title: Application expert (PL34)	Date: 2020.10.07 Place of issue: Vejle, DK	Approved by  Signature: Name: Tom Toft Kragh Title: Senior Director, RH-D, R&D
--	--	--	---

Danfoss only vouches for the correctness of the English version of this declaration. In the event of the declaration being translated into any other language, the translator concerned shall be liable for the correctness of the translation

TULKOJUMS

Danfoss A/S
DK-6430 Nordborg
Dānija
CVR nr.: 2016 57 15
Tel. +45 7488 2222
Faks. +45 7449 0949

RAŽOTĀJA DEKLARĀCIJA

Danfoss A/S

Grīdas apsilde un Elektroniskā kontrole, Apkures segments

deklarē ar pilnu atbildību, ka

Produktu kategorija: Kolektori**Tipa apzīmējums (-i):** **SSM-F** (nerūsējoša tērauda kolektori ar plūsmas mērītājiem)


Uz kuriem attiecas šī deklarācija ir atbilstībā ar sekojošām direktīvām, standartiem vai citiem minētiem normatīviem dokumentiem, un kuri ir jāpielieto saskaņā ar ražotāja instrukcijām.

- PEX caurules ir saskaņā ISO15875 un PERT caurules ir saskaņā ar ISO22391 sekojošiem izmēriem:
 - o 12x2mm, 13x2mm, 14x2mm, 15x2,5mm, 16x1,5mm, 16x2mm, 16x2,2mm, 17x2mm, 18x2mm, 18x2,5mm, 20x2mm, 20x2,25mm un 20x2,5mm
- Var izmantot sekojošiem SSM-F kolektoriem:
 - o 088U0752, 088U0753, 088U0754, 088U0755, 088U0756, 088U0757, 088U0758, 088U0759, 088U0760, 088U0761, 088U0762 ar nosacījumu, ka tiek izmantoti atbilstoši piederumi.

Datums: 2020.10.07	Izdevis (paraksts)	Datums: 2020.10.07	Apstiprināts: (paraksts)
Vejle, DK	Vārds, Uzvārds: Peter Skov Kjeldsteen Amats: Aplikāciju eksperts (PL34)	Vejle, DK	Vārds, Uzvārds: Tom Toft Kragh Amats: Vecākais direktors, RH-D, R&D

Danfoss uzņemas pilnu atbildību par ražotāja deklarācijas versiju angļu valodā. Gadījumos par deklarācijas tulkošanu citā valodā tulks uzņemas atbildību par deklarācijas pareizu tulkojumu.

Tulkoja: Irena Omelana, SIA Danfoss, Pārdošanas atbalsta speciāliste
ID nr. BF356751118147lv-000101 Versijas Nr. 01



Lapa 1 no 1