



This certifies that

DANFOSS A/S

has had the undermentioned product(s) examined, tested and certified as being of an appropriate quality and standard as required in the Water Supply (Water Fittings) Regulations and Scottish Water Byelaws, subject to scheme requirements being met when installed.

Model Numbers

**XB06 COPPER AND STAINLESS STEEL (316/1.4401)
PLATE HEAT EXCHANGERS**

The certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Approvals Directory (www.wras.co.uk/directory)

The product so mentioned will be valid until the end of:

October 2026

Certificate No.

2110022

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a long horizontal flourish extending to the right.

Ian Hughes,
WRAS Approvals Manager

APPROVAL INFORMATION

Validity dates:	This approval is valid for fittings (as listed below in model) manufactured AND installed between October 2021 & October 2026
Section Number:	1350
Section title:	HEAT EXCHANGERS
Installation requirement notes:	R001 (IRN's are set out in Appendix A)
Product description:	Copper brazed micro plate heat exchanger with copper and stainless-steel (316/1.4401) plates. Maximum working pressure 25.0 Bar. Maximum operating temperature 100 °C
Size:	¾" BSP (M)
Identification Marking:	Danfoss company logo, model name, maximum temperature and pressure, date of manufacture (YYYY-MM-DD) and other technical information on adhesive label on front of heat exchanger.
Manufacturer:	Danfoss Trata d.o.o.
Factor:	Danfoss A/S
Model:	XB06

APPENDIX A

INSTALLATION REQUIREMENTS & NOTES

You are advised to draw customers' attention to the installation requirements and notes set out below which must be followed to ensure that the fittings described above are installed in accordance with the requirements of the Regulations and Byelaws:

IRN R001

See text of entry for Installation Requirements or Notes.