



This certifies that

DANFOSS A/S

has had the undermentioned product(s) examined, tested and certified as being of an appropriate quality and standard as required in the Water Supply (Water Fittings) Regulations and Scottish Water Byelaws, subject to scheme requirements being met when installed.

Model Numbers

**PRESSURE TRANSMITTER SERIES DST P1XX:
DST P100.**

**DST P110.
DST P140.**

The certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Approvals Directory (www.wras.co.uk/directory)

The product so mentioned will be valid until the end of:

January 2026

Certificate No.

2101068

A handwritten signature in blue ink, appearing to read 'Ian Hughes', written in a cursive style.

Ian Hughes,
WRAS Approvals Manager

APPROVAL INFORMATION

Validity dates:	This approval is valid for fittings (as listed below in model) manufactured AND installed between January 2021 & January 2026 Additions to the approval are valid from the date of the addition
Section Number:	1530
Section title:	MISCELLANEOUS FITTINGS
Installation requirement notes:	R001 (IRN's are set out in Appendix A)
Product description:	Range of pressure transmitters with stainless steel bodies. Maximum working pressures: DST-P140 model 25.0 bar, all other models 50.0 bar. Maximum operating temperature 90°C.
Size:	DST P100: 1/8" NPT (M) & 1/4" BSP (M). DST P110: 1/4" NPT (M) & 1/2" BSP (M). DST P140: 1/2" NPT (M). Size added June 2022: DST P140: 1/4" BSP (M).
Identification Marking:	DANFOSS, model number, CE and operating pressure range on body.
Manufacturer:	Danfoss Tianjin Ltd.
Factor:	Danfoss A/S
Model:	Pressure Transmitter series DST P1XX: DST P100. DST P110. DST P140.

APPENDIX A

INSTALLATION REQUIREMENTS & NOTES

You are advised to draw customers' attention to the installation requirements and notes set out below which must be followed to ensure that the fittings described above are installed in accordance with the requirements of the Regulations and Byelaws:

IRN R001

See text of entry for Installation Requirements or Notes.