

**Danfoss A/S**6430 Nordborg  
Denmark  
CVR nr.: 20 16 57 15Telephone: +45 7488 2222  
Fax: +45 7449 0949**EU DECLARATION OF CONFORMITY****Danfoss A/S  
Danfoss Climate Solutions**

declares under our sole responsibility that the

**Product category: Brazed plate heat exchangers****Type designation(s):****Product in category I-III**



XB\*, B3\*, H22, H30, H34, H55, H62, H117, H118, H212, C22, C30, C55, C62, C117, C118, C212, D22, D30, D55, D62, D117, D118, D212, SL/SLS32TL, SL32TLDW, SL/SLS34TL, SL34TLDW, SL/SLS70TL/TK/TM, SL70TLDW/TMDW/TKDW, SL78TL,

SL/SLS140TL/ TK/TM, SL140TKDW/TLDW, SL222TL, SL333TL/TK/TM/TLX

HEX type	Fluid group	PS	min NOP	max NOP
SL140TK	Group 1	34	9	183
SL140TL	Group 1	34	9	183
SL140TM	Group 1	34	9	183
SL222TL	Group 1	16	11	224
SL222TL	Group 1	25	7	143
SL333TK	Group 1	16	5	105
SL333TK	Group 1	25	3	67
SL333TL	Group 1	16	7	153
SL333TL	Group 1	25	4	98
SL333TM	Group 1	16	7	153
SL333TM	Group 1	25	4	98
SL333TLX	Group 1	25	5	118
SL333TLX	Group 1	16	9	184

Conformity assessment procedure according to Module H - Full quality assurance.

Certificate no. H: **N° CE-0062-PED-H-DAF 001-21-DNK-rev-A****Product in category IV:**

Date: 2023.03.15 Place of issue: Kamnik	Issued by  Signature: Name: Kaike Xu Title: Director, PPM	Date: 2023.03.15 Place of issue: Kamnik	Approved by  Signature: Name: Gregory Touron Title: Director, BPHE RD&E
--------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Danfoss only vouches for the correctness of the English version of this document. In the event of the document being translated into any other language, the translator concerned must be liable for the correctness of the translation.

SL140TL/TK/TM, SL222TL, SL333TL/TK/TM/TLX

HEX type	Fluid group	PS	min NOP	max NOP
SL140TK	Group 1	34	184	200
SL140TL	Group 1	34	184	200
SL140TM	Group 1	34	184	200
SL222TL	Group 1	16	225	300
SL222TL	Group 1	25	144	300
SL333TK	Group 1	16	106	360
SL333TK	Group 1	25	68	360
SL333TL	Group 1	16	154	360
SL333TL	Group 1	25	99	360
SL333TM	Group 1	16	154	360
SL333TM	Group 1	25	99	360
SL333TLX	Group 1	25	119	360
SL333TLX	Group 1	16	185	360

Conformity assessment procedure according to Module H1 - Full quality assurance plus design examination.

Certificates issued:

Certificate no. H1: **N° CE-0062-PED-H1-DAF 001-21-DNK-rev-A**

EU Design Examination certificate: **N° CE-0062-PED-H1D-DAF 001-21-DNK**



Covered by this declaration is in conformity with the following directive(s), regulation(s), standard(s) or other normative document(s), provided that the product is used in accordance with our instructions.

### Pressure Equipment Directive 2014/68/EU

EN 13445-1:2021	Unfired pressure vessels – Part 1: General
EN 13445-2:2021	Unfired pressure vessels – Part 2: Materials
EN 13445-3:2021	Unfired pressure vessels – Part 3: Design
EN 13445-4:2021	Unfired pressure vessels – Part 4: Fabrication
EN 13445-5:2021	Unfired pressure vessels – Part 5: Inspection and testing

A risk assessment has been performed and documented according to Annex I.

Products belong to PED Article 4 paragraph 3 (Art. 4.3) are not CE marked.

Date: 2023.03.15 Place of issue: Kamnik	<b>Issued by</b>  <b>Signature:</b> <b>Name: Kaike Xu</b> <b>Title: Director, PPM</b>	Date: 2023.03.15 Place of issue: Kamnik	<b>Approved by</b>  <b>Signature:</b> <b>Name: Gregory Touron</b> <b>Title: Director, BPHE RD&amp;E</b>
--------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------



Danfoss only vouches for the correctness of the English version of this document. In the event of the document being translated into any other language, the translator concerned must be liable for the correctness of the translation.



Products in category I, II, III and IV are marked with **CE**0062 and evaluated by:

**BUREAU VERITAS SERVICES**

8 Cours du Triangle  
92800 PUTEAUX - LA DEFENSE  
France

<p>Date: 2023.03.15 Place of issue: Kamnik</p>	<p>Issued by  Signature: Name: Kaike Xu Title: Director, PPM</p>	<p>Date: 2023.03.15 Place of issue: Kamnik</p>	<p>Approved by  Signature: Name: Gregory Touron Title: Director, BPHE RD&amp;E</p>
------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Danfoss only vouches for the correctness of the English version of this document. In the event of the document being translated into any other language, the translator concerned must be liable for the correctness of the translation.