



Danfoss A/S

6430 Nordborg
Denmark
CVR nr.: 20 16 57 15

Telephone: +45 7488 2222
Fax: +45 7449 0949

MANUFACTURER’S DECLARATION

Danfoss A/S

HydronicS Division, Danfoss Climate Solutions Segment

declares under our sole responsibility that the

Product category: Plastic pipes

Type designation(s):

PEX-A plastic pipes are used for heating installations.

- 088X0872 FH PEX-A EVOH 5 Layer 16x2.0 400m (ES)
- 088X0873 FH PEX-A EVOH 5 Layer 16x2.0 600m (ES)
- 088X0874 FH PEX-A EVOH 5 Layer 18x2.0 240m (ES)
- 088X0875 FH PEX-A EVOH 5 Layer 18x2.0 600m (ES)
- 088X0877 FH PEX-A EVOH 5 Layer 20x2.0 400m (ES)



Covered by this declaration is in conformity with the following directive(s), regulation(s), standard(s) or other normative document(s), provided that the product is used in accordance with our instructions.

- EN ISO 15875-2:2003 Plastics piping systems for hot and cold water installations — Crosslinked polyethylene (PE-X) — Part 2: Pipes, including A1:2007 and A2:2020
 - 16 x 2 mm Class 1, 2 and 4 / 10 bar
 Class 5 / 8 bar
 - 18 x 2 mm Class 1, 2 and 5 / 8 bar
 Class 4 / 10 bar
 - 20 x 2 mm Class 1 and 4 / 8 bar
 Class 2 and 5 / 6 bar
- DIN 4726:2017 Warm water surface heating systems and radiator connecting systems - Plastics piping systems and multilayer piping systems

<p>Date: 17 January 2024</p> <p>Place of issue: Ljubljana</p>	<p>Issued by DocuSigned by: Samo Krančan 49CB37CCBD05404...</p> <p>Signature: Name: Samo Krančan Title: Sustainability and Compliance Director</p>	<p>Date: 19 January 2024</p> <p>Place of issue: Kolding, DK</p>	<p>Approved by DocuSigned by: Nanna Aage Lundsgaard 02743C4E8E8A4FD...</p> <p>Signature: Name: Nanna Aage Lundsgaard Title: Vice President, Head of RD&E, Hydronic Division</p>
---	--	---	---

Danfoss only vouches for the correctness of the English version of this declaration. In the event of the declaration being translated into any other language, the translator concerned shall be liable for the correctness of the translation

- DIN 16892:2018 Crosslinked polyethylene (PE-X) pipes - General quality requirements, testing
- DIN 16893:2018 Crosslinked polyethylene (PE-X) pipes - Dimensions

<div>Date: 17 January 2024</div> <div>Place of issue: Lubjana</div>	<div>Issued by DocuSigned by:  49CB37CCBD05404...</div> <div>Signature: Name: Samo Krančan Title: Sustainability and Compliance Director</div>	<div>Date: 19 January 2024</div> <div>Place of issue: Kolding, DK</div>	<div>Approved by DocuSigned by:  02742C4F8E8A4FD...</div> <div>Signature: Name: Nanna Aage Lundsgaard Title: Vice President, Head of RD&E, Hydronic Division</div>
---	---	---	--

Danfoss only vouches for the correctness of the English version of this declaration. In the event of the declaration being translated into any other language, the translator concerned shall be liable for the correctness of the translation