

EUROPEAN UNION RECOGNISED ORGANISATION (EU RO) MUTUAL RECOGNITION TYPE APPROVAL CERTIFICATE

Certificate No: MRA00003B Revision No:

In accordance with Article 10.1 of EU Regulation 391/2009

This Certificate is issued to

Danfoss A/S Nordborg, Syddanmark, Denmark

for

Pressure Gauges/Transmitters

with type designation(s)

DST P40M

The product is found to comply with

EU RO Mutual Recognition Technical Requirements for Pressure Gauges - Transmitters

Intended service

Pressure transmitters for use in control, alarm, monitoring and instrumentation systems subject to classification.

Temperature [°C]: -25 to 70
Vibration: ± 1.6 mm / 4.0g
EMC: Bridge and deck zone

IP Code: 65 / 67 (for Plug DT04-4P-CE04 with cable)

This is to certify:

that the Product referred to herein has been inspected for the Manufacturer, pursuant to the relevant requirements of the European Union Recognised Organisation Mutual Recognition procedure, required by Article 10.1 of EU Regulation 391/2009, and has been found in accordance with those requirements.

This Certificate is valid until 2026-04-20.

Issued at Høvik on 2025-03-04

DNV local unit: Denmark CMC

Approval Engineer: Sonali Marathe

for DNV

This document has been digitally signed and will therefore not have handwritten signature

Frederik Tore Elter Head of Section

Form code: MRTA 201 Revision: 2024-10 www.dnv.com Page 1 of 4

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.

The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Job Id: **262.4-000222-2** Certificate No: **MRA000003B**

Revision No: 1

Product description

Pressure transmitter for marine applications: DST P40M

Designed for use in corrosive industrial environments such as desalination systems, medical industry, chemical processing, chlorate containing liquids, hydro-carbon processing, etc.

- Enclosure Titanium grade 2
- Temperature compensated
- Reverse polarity protected
- Gauge (relative)
- Wetted parts: Titanium & Ceramic
- Ceramic Al2O3 96%
- High linearity and low hysteresis value
- RoHS compliance

Pressure range -1 bar to 100 bar

Output Signal 4-20 mA Power supply 24 VDC Electrical connection

Plug DT04-4P-CE04 and others, refer to datasheet (Al354625841155en-000101)

Pressure connection

G1/4" and G1/2" (ISO 1179-2)

M14x1.5, DIN3852-E

Manufactured by

Danfoss A/S, Nordborgvej 81, DK-6430 Nordborg, Denmark

Danfoss (Tianjin) Ltd, Wuqing Development Area, 9 Quanhui Road, 301700 Tianjin, China

Application/Limitation

Applicable for a ship as defined in Mutual Recognition Provisions Article 10 Regulation on Common Rules and standards For Ship Inspection and Survey Organizations.

Type Approval documentation

Name	Number	Date
Pressure transmitters for marine applications DST P40M	Al354625841155en-000101	2021-01
Accredited Marine type tests DST P40M	TR078G0047	2021-02-01
IP X5 test of 078G5020	121-23459-1	2021-02-23
IP 6X test of DST P40M	121-25556-1	2021-04-14
Engineering Sheet	ESH078G5045 (Version 00)	2024-03-22
Water intrusion test (IP67) report for Seawater cable version sensor - 078G5045 (DT04-4P-CE04 with cable)	CTR060G0015 2025-0	
EU RO MR TA PQA Scheme periodical assessment checklist	-	2021-04-21

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Other Conditions

The pressure transmitters have been verified for compliance with EU Mutual Recognition Technical Requirements for Pressure gauges – transmitters version 0.3.

Environmental	test parameters	DNV location classes
Temperature:	-25°C ~ +70°C	D
Vibration:	±1.6 mm / 4.0 g	В
Humidity:	95%RH @ 55°C, damp heat cyclic	В
EMC:	Bridge and deck zone (tested to 6 GHz)	В
Enclosure:	IP65 (IP67 for Plug DT04-4P-CE04 with cable), Salt mist	В
	test and flammability test.	
	(IP-ratings according to IEC 60529)	

Form code: MRTA 201 Revision: 2024-10 www.dnv.com Page 2 of 4



Job Id: **262.4-000222-2** Certificate No: **MRA000003B**

Revision No: 1

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed annually and at renewal of this certificate.

END OF CERTIFICATE

Form code: MRTA 201 Revision: 2024-10 www.dnv.com Page 3 of 4



Job Id: **262.4-000222-2** Certificate No: **MRA000003B**

Revision No: 1

Generic Statement for EU RO MR Type Approval Certificate

When a product is presented with this EU RO MR Type Approval Certificate for given application, its acceptability with regards to the limitations stated in the certificate conditions defined in 1b, 1c and 1d of the applied Technical Requirement will be evaluated by the EU RO in charge of classing the ship or being in charge of the unit/system certification.

In accordance with Article 10 of Regulation (EC) No 391/2009 of the European Parliament and of the Council of 23 April 2009 "on common rules and standards for ship inspection and survey organizations", the following organizations, recognized by the EU on this date, have agreed on the technical and procedural conditions under which they will mutually recognize this certificate:

- · American Bureau of Shipping (ABS);
- Bureau Veritas (BV);
- China Classification Society (CCS);
- · Croatian Register of Shipping (CRS);
- DNV;
- Indian Register of Shipping (IRS);
- Korean Register (KR):
- · Lloyd's Register Group Ltd. (LR);
- Nippon Kaiji Kyokai General Incorporated Foundation (ClassNK);
- Polish Register of Shipping (PRS);
- RINA Services S.p.A. (RINA).

The scheme for the mutual recognition of class certificates for materials, equipment and components laid down by Article 10(1) of Regulation (EC) No 391/2009 is only enforceable within the Union in respect of ships flying the flag of a Member State. As far as foreign vessels are concerned, the acceptance of relevant certificates remains at the discretion of relevant non-EU flag States in the exercise of their exclusive jurisdiction, notably under the United Nations Convention on the Law of the Sea (UNCLOS). (In accordance with COMMISSION IMPLEMENTING REGULATION (EU) No 1355/2014 amending Regulation (EC) No 391/2009 - recital (25)).

Form code: MRTA 201 Revision: 2024-10 www.dnv.com Page 4 of 4