

CERTIFICATE NUMBER EFFECTIVE DATE EXPIRY DATE ABS TECHNICAL OFFICE 25-0336453-PDA 10-Sep-2025 09-Sep-2030 Gdynia Engineering Department

CERTIFICATE OF

Product Design Assessment

This is to certify that a representative of this Bureau did, at the request of

DANFOSS A/S

located at

NORDBORGVEJ 81, , NORDBORG, Denmark, DK-6430

assess design plans and data for the below listed product. This assessment is a representation by the Bureau as to the degree of compliance the design exhibits with applicable sections of the Rules. This assessment does not waive unit certification or classification procedures required by ABS Rules for products to be installed in ABS classed vessels or facilities. This certificate, by itself, does not reflect that the product is Type Approved. The scope and limitations of this assessment are detailed on the pages attached to this certificate.

Product: Temperature Sensor

Model: MBT 5310 / 5410 / 5722

Endorsements:

Tier: 2 - PDA Issued

This Product Design Assessment (PDA) Certificate remains valid until 09/Sep/2030 or until the Rules and/or Standards used in the assessment are revised or until there is a design modification warranting design reassessment (whichever occurs first).

Acceptance of product is limited to the "Intended Service" details prescribed in the certificate and as per applicable Rules and Standards.

This Certificate is valid for installation of the listed product on ABS units which exist or are under contract for construction on or previous to the effective date of the ABS Rules and standards applied at the time of PDA issuance. Use of the Product for non-ABS units is subject to agreement between the manufacturer and intended client.

American Bureau Of Shipping

Arkadiusz Pytkowski, Engineer/Consultant

NOTE: This certificate evidences compliance with one or more of the Rules, Guides, standards or other criteria of ABS or a statutory, industrial or manufacturer's standards. It is issued solely for the use of ABS, its committees, its clients or other authorized entities. Any significant changes to the aforementioned product without approval from ABS will result in this certificate becoming null and void. This certificate is governed by ABS Rules 1-1-A3/5.9 Terms and Conditions of the Request for Product Type Approval and Agreement (2010)

DANFOSS A/S

NORDBORGVEJ 81

NORDBORG

Denmark DK-6430

Telephone: 45-7488-2222

Fax: 45-7465 2580

Email: danfoss@danfoss.com Web: www.danfoss.com

Tier: 2 - PDA Issued

Product: Temperature Sensor
Model: MBT 5310 / 5410 / 5722

Endorsements:

Intended Service:

For use on ABS classed vessels and offshore facilities in accordance with the listed ABS Rules and International Standards

Description:

Temperature Sensors with Fixed Measuring Insert

Rating:

MBT 5310 Measuring range: -50 to +200°C MBT 5410 Measuring range: -50 to +100°C MBT 5722 Measuring range: -50 to +200°C

Service Restriction:

Unit Certification is not required for this product.

If the manufacturer or purchaser request an ABS Certificate for compliance with a specification or standard, the specification or standard, including inspection standards and tolerances, must be clearly defined.

Comments:

The Manufacturer has provided a declaration about the control of, the lack of Asbestos in this product.

Notes/Drawing/Documentation:

Drawing No. AI202186432661en-000801, Data Sheet - Temperature sensor Type (MBT 5410), Revision: -, Pages: 5

Drawings received originally:

Drawing No. 117-34687-2, EMC Marine test of high temperature sensors, Revision: n/a, Date: 01-Apr-2020, Force Technology, Pages: 1

Drawing No. IC.PD.P30.J7.02_MBT5410_MS, MBT 5410, Revision: n/a, Pages: 1 Drawing No. IC.PD.P30.M7.02_MBT5722_MS, MBT 5722, Revision: n/a, Pages: 1 Drawing No. IC.PD.P30.Q4.02_MBT5310_MS, MBT 5310, Revision: n/a, Pages: 1

Terms of Validity:

This Product Design Assessment (PDA) Certificate remains valid until 09/Sep/2030 or until the Rules and/or Standards used in the assessment are revised or until there is a design modification warranting design reassessment (whichever occurs first).

Acceptance of product is limited to the "Intended Service" details prescribed in the certificate and as per applicable Rules and Standards.

This Certificate is valid for installation of the listed product on ABS units which exist or are under contract for construction on or previous to the effective date of the ABS Rules and standards applied at the time of PDA issuance. Use of the Product for non-ABS units is subject to agreement between the manufacturer and intended client.

STANDARDS

ABS Rules:

Rules for Conditions of Classification, Part 1 - 2025 Marine Vessel Rules 1A-1-4/7.7, 1A-1-A3, 1A-1-A4, which

DANFOSS A/S

NORDBORGVEJ 81

NORDBORG

Denmark DK-6430

Telephone: 45-7488-2222

Fax: 45-7465 2580

Email: danfoss@danfoss.com Web: www.danfoss.com

Tier: 2 - PDA Issued

covers the following:

2025 Marine Vessels Rules: 4-1-1/3.3, 4-1-1/7.15, 4-8-3/1.7, 4-9-9/7, 4-9-9/13, 4-9-9/15.7 Table1

Rules for Conditions of Classification, Part 1B - 2025 Offshore Units and Structures 1B-1-4/9.7, 1B-1-A2, 1B-1-A3, which covers the following:

2025 Offshore Units Rules: 4-1-1/7.9, 4-3-1/11, 6-1-1/9, 6-1-1/13

National:

NA

International:

IACS UR E10 Rev.9:2023

Government:

NA

EUMED:

NA

OTHERS:

NA