

This certifies that

DANFOSS A/S

has had the undermentioned product(s) examined, tested and certified as being of an appropriate quality and standard as required in the Water Supply (Water Fittings) Regulations and Scottish Water Byelaws, subject to scheme requirements being met when installed.

Model Numbers

132U1000 (EV221BW 10BE G38E NC000), 132U1002 (EV221BW 10BE G12E NC000), 132U1300 (EV221BW 14BE G12E NC000), 132U2002 (EV221BW 20BE G34E NC000) & 132U2200 (EV221BW 22BE G1E NC000) SOLENOID VALVES.

The certificate by itself is not evidence of a valid WRAS Approval. Confirmation of the current status of an approval must be obtained from the WRAS Approvals Directory (www.wras.co.uk/directory)

The product so mentioned will be valid until the end of:

May 2027

Certificate No.

2205077

lan Hughes, WRAS Approvals Manager Approval Number: 2205077 1st July 2022

APPROVAL INFORMATION

Validity dates: This approval is valid for fittings (as listed below in model) manufactured AND installed between

May 2022 & May 2027

Section Number: 2230

Section title: VALVES SOLENOID, METAL.

Installation requirement

R001

notes: (IRN's are set out in Appendix A)

Product description: EV221BW range of normally closed solenoid valves with brass bodies, EPDM diaphragms and 'O'-

rings.

Maximum working pressure 10.0 bar. Maximum operating temperature 85°C.

Note: The products must only be used with Danfoss branded coils.

Size: See model.

Identification Marking: 132U1000, 132U1002 and 132U2200 models: Danfoss and flow arrow on body DANFOSS A/S, model

and made in Poland on armature tube. 132U1300 and 132U2002 models: Flow arrow on body.

DANFOSS A/S, model and made in Poland on armature tube.

Manufacturer: Danfoss Poland Sp. z o.o.

Factor: Danfoss A/S

Model: 132U1000 (EV221BW 10BE G38E NC000): 3/8" BSP (F) inlet and outlet,

132U1002 (EV221BW 10BE G12E NC000): $\frac{1}{2}$ " BSP (F) inlet and outlet, 132U1300 (EV221BW 14BE G12E NC000): $\frac{1}{2}$ " BSP (F) inlet and outlet, 132U2002 (EV221BW 20BE G34E NC000): $\frac{3}{4}$ " BSP (F) inlet and outlet, 132U2200 (EV221BW 22BE G1E NC000): 1" BSP (F) inlet and outlet.

Approval Number: 2205077 1st July 2022

APPENDIX A

INSTALLATION REQUIREMENTS & NOTES

You are advised to draw customers' attention to the installation requirements and notes set out below which must be followed to ensure that the fittings described above are installed in accordance with the requirements of the Regulations and Byelaws:

IRN R001

See text of entry for Installation Requirements or Notes.