



TYPE APPROVAL CERTIFICATE

Certificate No:
TAA000012Z
Revision No:
1

This is to certify:

That the **Temperature Sensor**

with type designation(s)
MBT 5410

Issued to

Danfoss A/S
Nordborg, Syddanmark, Denmark

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Temperature Sensors. Resistance Thermometer.

Location classes:

Temperature	D
Humidity	B
Vibration	A
EMC	A
Enclosure	C

Issued at **Høvik** on **2022-12-20**

for **DNV**

This Certificate is valid until **2026-10-27**.

DNV local unit: **Denmark CMC**

Approval Engineer: **Martin Skårerverket**

.....
Frederik Tore Elter
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2022-09

www.dnv.com

Page 1 of 2

Product description

Resistance Thermometer (Pt-100 or Pt-1000) Type: MBT 5410
Direct connection to Pt element
Diameter: 8 mm
Length: 60-100 mm
Material: AISI316Ti
Temperature: -50 to 100 °C
Response time (water 0.2m/s): Z 0.5 = 8.7 s, Z 0.9 = 24.6 s

Place of manufacture

Danfoss (Tianjin) Ltd
Wuqing Development Area, 9 Quanhui Road,
301700 Tianjin, China

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Application/Limitation

Not for applications where flameproof or intrinsically safe equipment is required.
Output 4 - 20 mA with MBT 9110 covered by TAA000013F

Type Approval documentation

Datasheet: AI202186432661en-000801 dated 2021-02
Drawing: 084M1016 v. 00
Test Reports: EC 327520 dated 1990-01-17 and EC 285120 dated 1990-02-22
CS-LF 2000135 dated 2000-04-05
117-34687-2 dated 2020-04-01

Survey of Specifications for DANFOSS Sensors dated 28.11.95

Type approval renewal assessment report for TAA000012Z, DNV Tianjin 2022-10-17.

Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021.

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE