

ENGINEERING TOMORROW

User Guide

TP5001 Programmable Room Thermostat





User Guide TP5001 Programmable Room Thermostats

1 LCD Overview

Symbols	Function description	Symbols	Function description
Mon – Sun	Current set day	<u>}}</u>	Heating active
1234	Current on/off period	₩	Frost protect active
AM ITITI.ITITI PM ITITI'ITI	Current set time / parameter number in setup	<u>(</u> -)	Schedule mode
	Room temperature	曲	Away mode
88 %	Temperature indication	Î	RF Status (TP5001RF only)
l SET	Set temperature	P	Battery low indicator (TP5001B & TP5001RF only)



2 Buttons

Symbols	Function description
С С	Power on/off
Ŀ	Timer and program operation
м	Mode change / option setting
<>	Temperature / option setting selectors

3 Power ON/OFF

Turn the thermostat ON or OFF by pressing ().

4 Setting the Temperature

- Press < or > at any time to change the desired temperature value. **SET** is shown in the display.
- When releasing < or >, the display returns to showing the actual temperature.
- The adjustment step is 0.5 °C.

5 Select Away Mode

- Press **M** to enter Away mode and will be displayed.
- Away mode temperature can be set in parameter settings, P07.
- Press M again to exit Away mode.



User Guide TP5001 Programmable Room Thermostats

6 Set Timer

- Press (); **hh** flashes. Press < or > to adjust hour.
- Press () again; mm flashes. Press < or > to adjust minute.
- Press again; week flashes. Press < or > to adjust week.
- · Complete all adjustments. Press any button to exit (automatic exit after 6 seconds with no operation).

7 Advanced Programmable Timer

The Advanced Programmable Timer mode enables the setting of a timer-controlled program for automatic comfort temperature, and an energy-saving lower setback temperature if standard room comfort temperature is not required.

The function consists of 2 programs:

P1 with 4 events in 5 days (Mon. Tue. Wed. Thu. Fri.)	P2 with 4 events in 2 days (Sat. Sun.).
P1: Press 🕒 for 3 secs to display Mo. Tu. We. Th. Fr.	P2: Sa. Su. are now shown in the display.
 P1, Event 1: 1. Use < or > to select the start time. 2. Press ⊕ to accept the setting. 3. Use < or > to select the temperature. 4. Press ⊕ to accept the setting. 	 P2, Event 1: 1. Use < or > to select the start time. 2. Press ⊕ to accept the setting. 3. Use < or > to select the temperature. 4. Press ⊕ to accept the setting.
P1, Event 2-4: Repeat the Event 1 procedure for programming Event 2-4.	P2, Event 2-4: Repeat the Event 1 procedure for programming Event 2-4.

If schedule working mode is set to 24hr, only P1 program will be available, see parameter P01. Mo. to Su. will be set together with the same times and temperatures.

The thermostat will continue the 4-event program based on the present time and day.

To set and change the room temperature temporarily:

- 1. Press < or > at any time to change the desired temperature value. **SET** is shown in the display.
- 2. When releasing the < or >, the display returns to showing the actual temperature. This temperature change is only temporary and will be maintained only until the next programmed setting!

A default program provides timer control if the customer does not create own programs:

Days	Event 1		Event 2		Event 3		Event 4	
	Start time	Temp.						
Mo Fr.	6:30	20° C	8:30	15° C	16:30	20° C	22:30	15° C
Sa Su.	7:30	20° C	9:30	15° C	16:30	20° C	22:30	15° C

* 24hr mode default program same as Mo. - Fr. above.



User Guide TP5001 Programmable Room Thermostats

8 Set Control Parameters

Press **M** button for 6 seconds to enter the parameter setting mode. Press **M** for parameter selection and set the parameter range via < or >. Complete all adjustments.

To exit press (), which is available for this purpose (automatic exit after 20 seconds with no operation).

The digits indicate the set value as follows:

No.	Parameter settings	Settings range	Default
P01	Working mode	01: Manual 02: Schedule timer 5/2 day 03: Schedule timer 24hr	02
P02	Heat control mode	01: On/off load compensation 02: On/off standard	01
P03	Heat control start-up mode	01: Normal start control 02: Delayed start control 03: Optimised start control	01
P04	Temperature limit high	Between low (P05) and 35° C	35° C
P05	Temperature limit low	Between 5° C and high (P04)	5° C
P06	Frost protect temperature	Between 5° C and 15° C	5° C
P07	Away mode temperature	Between low (P05) and high (P04)	18° C
P08	Timer display	01: 24hr 02: 12hr	24hr
P09	Service due setup	Installer setting only	
P10	RF Pairing (TP5001RF only)	00: RF pairing mode off 01: RF pairing mode on	00

P03 to P08 appear on relevant temperature control mode.

9 Error Messages

E1	Room sensor failure
E2	Floor sensor failure
EE	EEPROM failure
Lo	Temperature lower than 0° C
Hi	Temperature higher than 50° C

All relay output will be turned off in all cases.

Danfoss Limited

Heating Segment • heating.danfoss.co.uk • +44 (0)1895 617000 • E-mail: customerservice.uk@danfoss.com

Danfoss can accept no responsibility for possible errors in catalogues, brochures and other printed material. Danfoss reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without subsequential changes being payary in specifications already agreed. All trademarks in this material are property of the respective expective payares. Danfoss for all parts respective and the payares are trademarks of Danfoss ArS. All right reserved.