

# Configuration of Modbus on AK-SM 800A

## Description

The AK-SM 800A sw. 3.2.6 is equipped with 2 Modbus channels, where we recommend:

- Modbus Channel 1 for Danfoss products
- Modbus Channel 2 for 3rd party products

They both have independent configuration properties and workflow.

## Modbus Channel 1

Channel MODBUS 1	Enabled	▼
Number of polls	1	
Number of Modbus Scan Ranges	1	
Modbus Address Low 1	0	
Modbus Address High 1	199	
SLV/CSENSE	No	▼

First of all the channel has to be enabled for the System Manager to connect to controllers. Once this is done the settings related to this will be presented for the user to choose.

Number of Polls:

Number of times the SM should try to attempt a request during scan

No. of Modbus Scan Ranges:

To reduce the amount of time taken when scanning it is possible to set up the ranges of address that is used at the site. It is possible to configure up to 3 ranges, and only these will be scanned by System Manager. Once the user chooses to set up a range, it is possible to configure a Low and high end for that range.

By default, the AK-SM 800 Modbus 1 channels has a set of attributes it is programmed with, for the user it is only possible to change the baud rate from 38400 to 19200 baud.

When **SLV/CSENSE** mode is enabled, the baud rate of this Modbus channel will be reduced to 19200.

**Modbus channel 2**

The Modbus channel 2 is only available in the later versions of AK-SM 800A, the unit used in this guide is of application version 3.2.6. And the intention is to use the Modbus 2 channel for 3rd party products that might have different communication attributes than the standard used in Danfoss ADAP-Kool® family.

Channel MODBUS 2	Enabled	▼
Number of Modbus Scan Ranges	1	
Modbus Address Low 1	0	
Modbus Address High 1	10	
No. of Modbus Configurations	2	
Modbus Configuration 1		
Baudrate	19200	▼
Parity	Even	▼
Databits	8	▼
Timeout (ms)	200	
Modbus Configuration 2		
Baudrate	38400	▼
Parity	Even	▼
Databits	8	▼
Timeout (ms)	200	

Like the Modbus 1 channel, this one also has to be enabled and it also possible to setup ranges, and they will be used for each configuration that is used on this channel.

The special part regarding the Modbus 2 channel is that, the user can define what configuration should be used. It is possible to configure up to 5 different ones.

Example:

The user configures 2 configurations with the following details:

	Modbus Configuration 1	Modbus Configuration 2
Baudrate	38400	19200
Parity	Even	None
Databits	8	8
Timeout (ms)	200	100

With this setup the System Manager will scan address 1 on the first configuration, then on the second configuration, and so on. Once it has either found a device or if no device has responded to the scan messages it will move on to the next address.

If a device has responded with an error message, it means that it is not the expected device type. In this case several messages are sent to try and positively identify the device type. If it can't be identified, it will be marked as an unknown device. This can then manually be changed in the scan status, where an ed3 file can be selected to use for this device. This however only applies to generic third-party devices, i.e. device types that are not normally supported.

1. Click on the gear wheel next to the address

Controllers					
33	084B4082	AK-CC55-013x	01.3x	Lon	
35	084B4081	AK-CC55-019x	01.9x	Modbus 1	
	36	084B8520	Uncfg	02.3B	Modbus 2
	37	084B4081	AK-CC55-019x	01.9x	Modbus 2
	40	080Z2800	DGS-011x	01.1x	Modbus 1
	50	084B8030	AK-CC550A-020x	02.0x	Modbus 1

2. On the page that opens click on the gear wheel again to get the list of controllers that are available to that particular System Manager and select the correct one.

**Device Type**

Model1
AK-CC210-023B

**Setting – Model**

Select the New Value

AHT-EKC-001x (AHT-EKC) s/w 001x
▼

AHT-EKC-001x (AHT-EKC) s/w 001x

- AHU-0403 (MC030001) MCX08M AHU Configure 1
- AK-CC210-023B (084B8520) app o61=2 s/w 2.30 - 2.39
- AK-CC210-023B (084B8534) app o61=2 s/w 2.30 - 2.39
- AK-CC210-023C (084B8520) app o61=3 s/w 2.30 - 2.39
- AK-CC210-023C (084B8534) app o61=3 s/w 2.30 - 2.39
- AK-CC210-023D (084B8520) app o61=4 s/w 2.30 - 2.39
- AK-CC210-023D (084B8534) app o61=4 s/w 2.30 - 2.39
- AK-CC210-023E (084B8520) app o61=5 s/w 2.30 - 2.39
- AK-CC210-023E (084B8534) app o61=5 s/w 2.30 - 2.39
- AK-CC210-023F (084B8520) app o61=6 s/w 2.30 - 2.39

The Modbus settings that a device was discovered on is stored, so that any subsequent messages to this device are sent using the correct Modbus settings.

Because there is some overhead with switching Modbus configurations, it is recommended to use the least number of configurations needed for the system.

**Note:**

- Schneider meters works only on Modbus channel 1, at 19200 for the moment.
- Do not use Danfoss controllers with auto baud rate detection Modbus 2 channel with more than one configuration, as the controllers will respond to both configurations.

**Danfoss A/S**

Climate Solutions • danfoss.com • +45 7488 2222

Any information, including, but not limited to information on selection of product, its application or use, product design, weight, dimensions, capacity or any other technical data in product manuals, catalogues descriptions, advertisements, etc. and whether made available in writing, orally, electronically, online or via download, shall be considered informative, and is only binding if and to the extent, explicit reference is made in a quotation or order confirmation. Danfoss cannot accept any responsibility for possible errors in catalogues, brochures, videos and other material. Danfoss reserves the right to alter its products without notice. This also applies to products ordered but not delivered provided that such alterations can be made without changes to form, fit or function of the product.

All trademarks in this material are property of Danfoss A/S or Danfoss group companies. Danfoss and the Danfoss logo are trademarks of Danfoss A/S. All rights reserved.