

Programming Guide

Modbus parameter list

AK-CC 350

SW Ver. 1.1x



Parameter list for AK-CC 350 (084B4165)
Application 1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
Thermostat control							
--- Cutout °C	100	20	-500	500	Float	R/W	0.1
r01 Differential	101	20	1	200	Float	R/W	0.1
r02 Max cutout °C	102	500	-490	500	Float	R/W	0.1
r03 Min cutout °C	103	-500	-500	490	Float	R/W	0.1
o17 Disp. S4 %	2021	100	0	100	Integer	R/W	1
r04 Disp. Adj. K	104	0	-200	200	Float	R/W	0.1
r05 Temp.unit	105	0	0	1	Integer	R/W	1
r09 Adjust S4	113	0	-100	100	Float	R/W	0.1
r10 Adjust S3	114	0	-100	100	Float	R/W	0.1
r13 Night offset	125	0	-100	100	Float	R/W	0.1
r15 Ther. S4 %	123	100	0	100	Integer	R/W	1
r39 Th. offset	150	0	0	1	Boolean	R/W	1
r40 Th. offset K	151	0	-500	500	Float	R/W	0.1
--- Night setbck	126	0	0	1	Boolean	R/W	1
--- Forced cool.	3044	0	0	1	Boolean	R/W	1
u28 Temp. ref.	2546	20	-2000	2000	Float	R	0.1
Compressor control							
c01 Min. On time	500	0	0	30	Integer	R/W	1
c02 Min.Off time	501	0	0	30	Integer	R/W	1
c30 Cmp relay NC	532	0	0	1	Boolean	R/W	1
c70 Ext. Relay	540	1	0	1	Boolean	R/W	1
Defrost control							
--- Def. Start	1013	0	0	1	Boolean	R/W	1
d01 Def. method	1000	1	0	3	Integer	R/W	1
d02 Def.StopTemp	1001	60	0	250	Float	R/W	0.1
d03 Def.Interval	1002	8	0	48	Integer	R/W	1
d04 Max Def.time	1003	45	0	180	Integer	R/W	1
d05 Time stagg.	1004	0	0	240	Integer	R/W	1
d06 DripOff time	1005	0	0	60	Integer	R/W	1
d07 FanStartDel	1007	0	0	60	Integer	R/W	1
d08 FanStartTemp	1006	-50	-150	0	Float	R/W	0.1
d09 FanDuringDef	1008	1	0	2	Integer	R/W	1
d10 DefStopSens.	1009	0	0	2	Integer	R/W	1
d16 Pump dwn del	1018	0	0	60	Integer	R/W	1
d18 MaxTherRunT.	1020	0	0	48	Integer	R/W	1
d19 CutoutSSDif.	1021	200	0	200	Float	R/W	0.1
--- HoldAfterDef	2022	0	0	1	Boolean	R/W	1
--- DefrostState	1036	0	0	1	Boolean	R	1
o16 MaxHoldTime	2020	20	0	60	Integer	R/W	1
Defrost schedules							
t01 Def. 1 hr.	1201	0	0	23	Integer	R/W	1
t11 Def. 1 min.	1211	0	0	59	Integer	R/W	1
t02 Def. 2 hr.	1202	0	0	23	Integer	R/W	1
t12 Def. 2 min.	1212	0	0	59	Integer	R/W	1
t03 Def. 3 hr.	1203	0	0	23	Integer	R/W	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
t13 Def. 3 min.	1213	0	0	59	Integer	R/W	1
t04 Def. 4 hr.	1204	0	0	23	Integer	R/W	1
t14 Def. 4 min.	1214	0	0	59	Integer	R/W	1
t05 Def. 5 hr.	1205	0	0	23	Integer	R/W	1
t15 Def. 5 min.	1215	0	0	59	Integer	R/W	1
t06 Def. 6 hr.	1206	0	0	23	Integer	R/W	1
t16 Def. 6 min.	1216	0	0	59	Integer	R/W	1
Fan control							
F01 Fan stop CO	1500	0	0	1	Integer	R/W	1
F02 Fan del. CO	1503	0	0	30	Integer	R/W	1
F04 FanStop temp	1505	500	-500	500	Float	R/W	0.1
Alarm settings							
A03 Alarm delay	10002	30	0	240	Integer	R/W	1
A04 DoorOpen del	10003	60	0	240	Integer	R/W	1
A12 Pulldown del	10018	90	0	240	Integer	R/W	1
A13 HighLim Air	10019	80	-500	500	Float	R/W	0.1
A14 LowLim Air	10020	-300	-500	500	Float	R/W	0.1
A27 Al.Delay DI1	10028	30	0	240	Integer	R/W	1
A28 Al.Delay DI2	10029	30	0	240	Integer	R/W	1
A36 Alarm S4 %	10037	100	0	100	Integer	R/W	1
--- Reset alarm	2046	0	0	1	Boolean	R/W	1
--- EKC Error	2541	0	0	1	Boolean	R	1
HACCP							
h01 HACCP temp °C	2094	1800	-2000	2000	Float	R	0.1
h10 Max temp.	2095	0	-2000	2000	Float	R	0.1
h11 HACCP sensor	2090	0	0	2	Integer	R/W	1
h12 HACCP limit	2091	80	-500	500	Float	R/W	0.1
h13 HACCP delay	2092	30	0	240	Integer	R/W	1
h14 HACCP S4%	2093	100	0	100	Integer	R/W	1
Miscellaneous							
o01 DelayOfOutp.	2000	5	0	600	Integer	R/W	1
o02 DI1 Config.	2001	0	0	11	Integer	R/W	1
o06 SensorConfig	2014	0	0	2	Integer	R/W	1
o37 DI2 Config.	2055	0	0	12	Integer	R/W	1
o46 Case clean	2056	0	0	2	Integer	R/W	1
Service							
u58 Comp1/LLSV	2510	0	0	1	Boolean	R/W	1
u60 Def. relay	2512	0	0	1	Boolean	R/W	1
u59 Fan relay	2511	0	0	1	Boolean	R/W	1
u62 Alarm relay	2583	0	0	1	Boolean	R/W	1
Alarm destinations							
--- EKC error	20000	0	0	1	Boolean	R	1
--- RTC error	20001	0	0	1	Boolean	R	1
--- S3 error	20002	0	0	1	Boolean	R	1
--- S4 error	20003	0	0	1	Boolean	R	1
--- S5 error	20004	0	0	1	Boolean	R	1
--- High t.alarm	20005	0	0	1	Boolean	R	1
--- Low t.alarm	20006	0	0	1	Boolean	R	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
--- HACCP alarm	20007	0	0	1	Boolean	R	1
--- Door alarm	20008	0	0	1	Boolean	R	1
--- DI1 alarm	20009	0	0	1	Boolean	R	1
--- DI2 alarm	20010	0	0	1	Boolean	R	1
--- Max Def.Time	20011	0	0	1	Boolean	R	1
--- Max HoldTime	20012	0	0	1	Boolean	R	1
--- Case clean	20013	0	0	1	Boolean	R	1
--- Standby mode	20014	1	0	1	Boolean	R	1
For DANFOSS only							
--- Appl.mode	2086	1	1	10	Integer	R	1
Module software	60001	0	0	1000	Float	R	0.01
Transceiver type	60006	3	0	1000	Integer	R	1
In All Groups							
r12 Main switch	117	0	-1	1	Integer	R/W	1
--- EKC State	2007	10	0	100	Integer	R	1
u17 Ther. air	2532	250	-2000	2000	Float	R	0.1
u12 S3 air temp.	2530	1200	-2000	2000	Float	R	0.1
u16 S4 air temp.	2531	250	-2000	2000	Float	R	0.1
u09 S5 temp.	1011	1200	-2000	2000	Float	R	0.1
u10 DI1 status	2002	0	0	1	Boolean	R	1
u13 Night Cond.	2533	0	0	1	Boolean	R	1
u37 DI2 status	2556	0	0	1	Boolean	R	1
u56 Display air	2576	250	-2000	2000	Float	R	0.1
u57 Alarm air	2578	250	-2000	2000	Float	R	0.1

Application 2

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
Thermostat control							
--- Cutout °C	100	20	-500	500	Float	R/W	0.1
r01 Differential	101	20	1	200	Float	R/W	0.1
r02 Max cutout °C	102	500	-490	500	Float	R/W	0.1
r03 Min cutout °C	103	-500	-500	490	Float	R/W	0.1
o17 Disp. S4 %	2021	100	0	100	Integer	R/W	1
r04 Disp. Adj. K	104	0	-200	200	Float	R/W	0.1
r05 Temp.unit	105	0	0	1	Integer	R/W	1
r09 Adjust S4	113	0	-100	100	Float	R/W	0.1
r10 Adjust S3	114	0	-100	100	Float	R/W	0.1
r13 Night offset	125	0	-100	100	Float	R/W	0.1
r15 Ther. S4 %	123	100	0	100	Integer	R/W	1
r39 Th. offset	150	0	0	1	Boolean	R/W	1
r40 Th. offset K	151	0	-500	500	Float	R/W	0.1
--- Night setbck	126	0	0	1	Boolean	R/W	1
--- Forced cool.	3044	0	0	1	Boolean	R/W	1
u28 Temp. ref.	2546	20	-2000	2000	Float	R	0.1
Compressor control							
c01 Min. On time	500	0	0	30	Integer	R/W	1
c02 Min.Off time	501	0	0	30	Integer	R/W	1
c30 Cmp relay NC	532	0	0	1	Boolean	R/W	1
c70 Ext. Relay	540	1	0	1	Boolean	R/W	1
Defrost control							
--- Def. Start	1013	0	0	1	Boolean	R/W	1
d01 Def. method	1000	1	0	3	Integer	R/W	1
d02 Def.StopTemp	1001	60	0	250	Float	R/W	0.1
d03 Def.Interval	1002	8	0	48	Integer	R/W	1
d04 Max Def.time	1003	45	0	180	Integer	R/W	1
d05 Time stagg.	1004	0	0	240	Integer	R/W	1
d06 DripOff time	1005	0	0	60	Integer	R/W	1
d07 FanStartDel	1007	0	0	60	Integer	R/W	1
d08 FanStartTemp	1006	-50	-150	0	Float	R/W	0.1
d09 FanDuringDef	1008	1	0	2	Integer	R/W	1
d10 DefStopSens.	1009	0	0	2	Integer	R/W	1
d16 Pump dwn del	1018	0	0	60	Integer	R/W	1
d18 MaxTherRunT.	1020	0	0	48	Integer	R/W	1
d19 CutoutSSDif.	1021	200	0	200	Float	R/W	0.1
--- HoldAfterDef	2022	0	0	1	Boolean	R/W	1
--- DefrostState	1036	0	0	1	Boolean	R	1
o16 MaxHoldTime	2020	20	0	60	Integer	R/W	1
Defrost schedules							
t01 Def. 1 hr.	1201	0	0	23	Integer	R/W	1
t11 Def. 1 min.	1211	0	0	59	Integer	R/W	1
t02 Def. 2 hr.	1202	0	0	23	Integer	R/W	1
t12 Def. 2 min.	1212	0	0	59	Integer	R/W	1
t03 Def. 3 hr.	1203	0	0	23	Integer	R/W	1
t13 Def. 3 min.	1213	0	0	59	Integer	R/W	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
t04 Def. 4 hr.	1204	0	0	23	Integer	R/W	1
t14 Def. 4 min.	1214	0	0	59	Integer	R/W	1
t05 Def. 5 hr.	1205	0	0	23	Integer	R/W	1
t15 Def. 5 min.	1215	0	0	59	Integer	R/W	1
t06 Def. 6 hr.	1206	0	0	23	Integer	R/W	1
t16 Def. 6 min.	1216	0	0	59	Integer	R/W	1
Fan control							
F01 Fan stop CO	1500	0	0	1	Integer	R/W	1
F02 Fan del. CO	1503	0	0	30	Integer	R/W	1
F04 FanStop temp	1505	500	-500	500	Float	R/W	0.1
Alarm settings							
A03 Alarm delay	10002	30	0	240	Integer	R/W	1
A04 DoorOpen del	10003	60	0	240	Integer	R/W	1
A12 Pulldown del	10018	90	0	240	Integer	R/W	1
A13 HighLim Air	10019	80	-500	500	Float	R/W	0.1
A14 LowLim Air	10020	-300	-500	500	Float	R/W	0.1
A27 Al.Delay DI1	10028	30	0	240	Integer	R/W	1
A28 Al.Delay DI2	10029	30	0	240	Integer	R/W	1
A36 Alarm S4 %	10037	100	0	100	Integer	R/W	1
--- Reset alarm	2046	0	0	1	Boolean	R/W	1
--- EKC Error	2541	0	0	1	Boolean	R	1
HACCP							
h01 HACCP temp °C	2094	1800	-2000	2000	Float	R	0.1
h10 Max temp.	2095	0	-2000	2000	Float	R	0.1
h11 HACCP sensor	2090	0	0	2	Integer	R/W	1
h12 HACCP limit	2091	80	-500	500	Float	R/W	0.1
h13 HACCP delay	2092	30	0	240	Integer	R/W	1
h14 HACCP S4%	2093	100	0	100	Integer	R/W	1
Miscellaneous							
o01 DelayOfOutp.	2000	5	0	600	Integer	R/W	1
o02 DI1 Config.	2001	0	0	11	Integer	R/W	1
o06 SensorConfig	2014	0	0	2	Integer	R/W	1
o37 DI2 Config.	2055	0	0	12	Integer	R/W	1
o38 Light config	2057	1	1	3	Integer	R/W	1
o39 Light remote	2058	0	0	1	Boolean	R/W	1
o46 Case clean	2056	0	0	2	Integer	R/W	1
Service							
u58 Comp1/LLSV	2510	0	0	1	Boolean	R/W	1
u60 Def. relay	2512	0	0	1	Boolean	R/W	1
u59 Fan relay	2511	0	0	1	Boolean	R/W	1
u63 Light relay	2584	0	0	1	Boolean	R/W	1
Alarm destinations							
--- EKC error	20000	0	0	1	Boolean	R	1
--- RTC error	20001	0	0	1	Boolean	R	1
--- S3 error	20002	0	0	1	Boolean	R	1
--- S4 error	20003	0	0	1	Boolean	R	1
--- S5 error	20004	0	0	1	Boolean	R	1
--- High t.alarm	20005	0	0	1	Boolean	R	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
--- Low t.alarm	20006	0	0	1	Boolean	R	1
--- HACCP alarm	20007	0	0	1	Boolean	R	1
--- Door alarm	20008	0	0	1	Boolean	R	1
--- DI1 alarm	20009	0	0	1	Boolean	R	1
--- DI2 alarm	20010	0	0	1	Boolean	R	1
--- Max Def.Time	20011	0	0	1	Boolean	R	1
--- Max HoldTime	20012	0	0	1	Boolean	R	1
--- Case clean	20013	0	0	1	Boolean	R	1
--- Standby mode	20014	1	0	1	Boolean	R	1
For DANFOSS only							
--- Appl.mode	2086	2	1	10	Integer	R	1
Module software	60001	0	0	1000	Float	R	0.01
Transceiver type	60006	3	0	1000	Integer	R	1
In All Groups							
r12 Main switch	117	0	-1	1	Integer	R/W	1
--- EKC State	2007	10	0	100	Integer	R	1
u17 Ther. air	2532	250	-2000	2000	Float	R	0.1
u12 S3 air temp.	2530	1200	-2000	2000	Float	R	0.1
u16 S4 air temp.	2531	250	-2000	2000	Float	R	0.1
u09 S5 temp.	1011	1200	-2000	2000	Float	R	0.1
u10 DI1 status	2002	0	0	1	Boolean	R	1
u13 Night Cond.	2533	0	0	1	Boolean	R	1
u37 DI2 status	2556	0	0	1	Boolean	R	1
u56 Display air	2576	250	-2000	2000	Float	R	0.1
u57 Alarm air	2578	250	-2000	2000	Float	R	0.1

Application 3

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
Thermostat control							
--- Cutout °C	100	20	-500	500	Float	R/W	0.1
r01 Differential	101	20	1	200	Float	R/W	0.1
r02 Max cutout °C	102	500	-490	500	Float	R/W	0.1
r03 Min cutout °C	103	-500	-500	490	Float	R/W	0.1
o17 Disp. S4 %	2021	100	0	100	Integer	R/W	1
r04 Disp. Adj. K	104	0	-200	200	Float	R/W	0.1
r05 Temp.unit	105	0	0	1	Integer	R/W	1
r09 Adjust S4	113	0	-100	100	Float	R/W	0.1
r10 Adjust S3	114	0	-100	100	Float	R/W	0.1
r13 Night offset	125	0	-100	100	Float	R/W	0.1
r15 Ther. S4 %	123	100	0	100	Integer	R/W	1
r39 Th. offset	150	0	0	1	Boolean	R/W	1
r40 Th. offset K	151	0	-500	500	Float	R/W	0.1
--- Night setbck	126	0	0	1	Boolean	R/W	1
--- Forced cool.	3044	0	0	1	Boolean	R/W	1
u28 Temp. ref.	2546	20	-2000	2000	Float	R	0.1
Compressor control							
c01 Min. On time	500	0	0	30	Integer	R/W	1
c02 Min.Off time	501	0	0	30	Integer	R/W	1
c30 Cmp relay NC	532	0	0	1	Boolean	R/W	1
c70 Ext. Relay	540	1	0	1	Boolean	R/W	1
Defrost control							
--- Def. Start	1013	0	0	1	Boolean	R/W	1
d01 Def. method	1000	1	0	3	Integer	R/W	1
d02 Def.StopTemp	1001	60	0	250	Float	R/W	0.1
d03 Def.Interval	1002	8	0	48	Integer	R/W	1
d04 Max Def.time	1003	45	0	180	Integer	R/W	1
d05 Time stagg.	1004	0	0	240	Integer	R/W	1
d06 DripOff time	1005	0	0	60	Integer	R/W	1
d07 FanStartDel	1007	0	0	60	Integer	R/W	1
d08 FanStartTemp	1006	-50	-150	0	Float	R/W	0.1
d09 FanDuringDef	1008	1	0	2	Integer	R/W	1
d10 DefStopSens.	1009	0	0	2	Integer	R/W	1
d16 Pump dwn del	1018	0	0	60	Integer	R/W	1
d18 MaxTherRunT.	1020	0	0	48	Integer	R/W	1
d19 CutoutSSDif.	1021	200	0	200	Float	R/W	0.1
--- HoldAfterDef	2022	0	0	1	Boolean	R/W	1
--- DefrostState	1036	0	0	1	Boolean	R	1
o16 MaxHoldTime	2020	20	0	60	Integer	R/W	1
Defrost schedules							
t01 Def. 1 hr.	1201	0	0	23	Integer	R/W	1
t11 Def. 1 min.	1211	0	0	59	Integer	R/W	1
t02 Def. 2 hr.	1202	0	0	23	Integer	R/W	1
t12 Def. 2 min.	1212	0	0	59	Integer	R/W	1
t03 Def. 3 hr.	1203	0	0	23	Integer	R/W	1
t13 Def. 3 min.	1213	0	0	59	Integer	R/W	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
t04 Def. 4 hr.	1204	0	0	23	Integer	R/W	1
t14 Def. 4 min.	1214	0	0	59	Integer	R/W	1
t05 Def. 5 hr.	1205	0	0	23	Integer	R/W	1
t15 Def. 5 min.	1215	0	0	59	Integer	R/W	1
t06 Def. 6 hr.	1206	0	0	23	Integer	R/W	1
t16 Def. 6 min.	1216	0	0	59	Integer	R/W	1
Fan control							
F01 Fan stop CO	1500	0	0	1	Integer	R/W	1
F02 Fan del. CO	1503	0	0	30	Integer	R/W	1
F04 FanStop temp	1505	500	-500	500	Float	R/W	0.1
Alarm settings							
A03 Alarm delay	10002	30	0	240	Integer	R/W	1
A04 DoorOpen del	10003	60	0	240	Integer	R/W	1
A12 Pulldown del	10018	90	0	240	Integer	R/W	1
A13 HighLim Air	10019	80	-500	500	Float	R/W	0.1
A14 LowLim Air	10020	-300	-500	500	Float	R/W	0.1
A27 Al.Delay DI1	10028	30	0	240	Integer	R/W	1
A28 Al.Delay DI2	10029	30	0	240	Integer	R/W	1
A36 Alarm S4 %	10037	100	0	100	Integer	R/W	1
--- Reset alarm	2046	0	0	1	Boolean	R/W	1
--- EKC Error	2541	0	0	1	Boolean	R	1
HACCP							
h01 HACCP temp °C	2094	1800	-2000	2000	Float	R	0.1
h10 Max temp.	2095	0	-2000	2000	Float	R	0.1
h11 HACCP sensor	2090	0	0	2	Integer	R/W	1
h12 HACCP limit	2091	80	-500	500	Float	R/W	0.1
h13 HACCP delay	2092	30	0	240	Integer	R/W	1
h14 HACCP S4%	2093	100	0	100	Integer	R/W	1
Miscellaneous							
o01 DelayOfOutp.	2000	5	0	600	Integer	R/W	1
o02 DI1 Config.	2001	0	0	11	Integer	R/W	1
o06 SensorConfig	2014	0	0	2	Integer	R/W	1
o37 DI2 Config.	2055	0	0	12	Integer	R/W	1
o41 Railh.ONday%	2060	100	0	100	Integer	R/W	1
o42 Railh.ONngt%	2061	100	0	100	Integer	R/W	1
o43 Railh.cycle	2062	10	6	60	Integer	R/W	1
o46 Case clean	2056	0	0	2	Integer	R/W	1
Service							
u58 Comp1/LLSV	2510	0	0	1	Boolean	R/W	1
u60 Def. relay	2512	0	0	1	Boolean	R/W	1
u59 Fan relay	2511	0	0	1	Boolean	R/W	1
u61 Railh. relay	2579	0	0	1	Boolean	R/W	1
Alarm destinations							
--- EKC error	20000	0	0	1	Boolean	R	1
--- RTC error	20001	0	0	1	Boolean	R	1
--- S3 error	20002	0	0	1	Boolean	R	1
--- S4 error	20003	0	0	1	Boolean	R	1
--- S5 error	20004	0	0	1	Boolean	R	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
--- High t.alarm	20005	0	0	1	Boolean	R	1
--- Low t.alarm	20006	0	0	1	Boolean	R	1
--- HACCP alarm	20007	0	0	1	Boolean	R	1
--- Door alarm	20008	0	0	1	Boolean	R	1
--- DI1 alarm	20009	0	0	1	Boolean	R	1
--- DI2 alarm	20010	0	0	1	Boolean	R	1
--- Max Def.Time	20011	0	0	1	Boolean	R	1
--- Max HoldTime	20012	0	0	1	Boolean	R	1
--- Case clean	20013	0	0	1	Boolean	R	1
--- Standby mode	20014	1	0	1	Boolean	R	1
For DANFOSS only							
--- Appl.mode	2086	3	1	10	Integer	R	1
Module software	60001	0	0	1000	Float	R	0.01
Transceiver type	60006	3	0	1000	Integer	R	1
In All Groups							
r12 Main switch	117	0	-1	1	Integer	R/W	1
--- EKC State	2007	10	0	100	Integer	R	1
u17 Ther. air	2532	250	-2000	2000	Float	R	0.1
u12 S3 air temp.	2530	1200	-2000	2000	Float	R	0.1
u16 S4 air temp.	2531	250	-2000	2000	Float	R	0.1
u09 S5 temp.	1011	1200	-2000	2000	Float	R	0.1
u10 DI1 status	2002	0	0	1	Boolean	R	1
u13 Night Cond.	2533	0	0	1	Boolean	R	1
u37 DI2 status	2556	0	0	1	Boolean	R	1
u56 Display air	2576	250	-2000	2000	Float	R	0.1
u57 Alarm air	2578	250	-2000	2000	Float	R	0.1

Application 4

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
Thermostat control							
--- Cutout °C	100	20	-500	500	Float	R/W	0.1
r01 Differential	101	20	1	200	Float	R/W	0.1
r02 Max cutout °C	102	500	-490	500	Float	R/W	0.1
r03 Min cutout °C	103	-500	-500	490	Float	R/W	0.1
o17 Disp. S4 %	2021	100	0	100	Integer	R/W	1
r04 Disp. Adj. K	104	0	-200	200	Float	R/W	0.1
r05 Temp.unit	105	0	0	1	Integer	R/W	1
r09 Adjust S4	113	0	-100	100	Float	R/W	0.1
r10 Adjust S3	114	0	-100	100	Float	R/W	0.1
r13 Night offset	125	0	-100	100	Float	R/W	0.1
r15 Ther. S4 %	123	100	0	100	Integer	R/W	1
r39 Th. offset	150	0	0	1	Boolean	R/W	1
r40 Th. offset K	151	0	-500	500	Float	R/W	0.1
--- Night setbck	126	0	0	1	Boolean	R/W	1
--- Forced cool.	3044	0	0	1	Boolean	R/W	1
u28 Temp. ref.	2546	20	-2000	2000	Float	R	0.1
Compressor control							
c01 Min. On time	500	0	0	30	Integer	R/W	1
c02 Min.Off time	501	0	0	30	Integer	R/W	1
c70 Ext. Relay	540	1	0	1	Boolean	R/W	1
Defrost control							
--- Def. Start	1013	0	0	1	Boolean	R/W	1
d01 Def. method	1000	2	0	3	Integer	R/W	1
d02 Def.StopTemp	1001	60	0	250	Float	R/W	0.1
d03 Def.Interval	1002	8	0	48	Integer	R/W	1
d04 Max Def.time	1003	45	0	180	Integer	R/W	1
d05 Time stagg.	1004	0	0	240	Integer	R/W	1
d06 DripOff time	1005	0	0	60	Integer	R/W	1
d07 FanStartDel	1007	0	0	60	Integer	R/W	1
d08 FanStartTemp	1006	-50	-150	0	Float	R/W	0.1
d09 FanDuringDef	1008	1	0	2	Integer	R/W	1
d10 DefStopSens.	1009	0	0	2	Integer	R/W	1
d16 Pump dwn del	1018	0	0	60	Integer	R/W	1
d17 Drain delay	1019	0	0	60	Integer	R/W	1
d18 MaxTherRunT.	1020	0	0	48	Integer	R/W	1
d19 CutoutS5Dif.	1021	200	0	200	Float	R/W	0.1
--- HoldAfterDef	2022	0	0	1	Boolean	R/W	1
--- DefrostState	1036	0	0	1	Boolean	R	1
o16 MaxHoldTime	2020	20	0	60	Integer	R/W	1
Defrost schedules							
t01 Def. 1 hr.	1201	0	0	23	Integer	R/W	1
t11 Def. 1 min.	1211	0	0	59	Integer	R/W	1
t02 Def. 2 hr.	1202	0	0	23	Integer	R/W	1
t12 Def. 2 min.	1212	0	0	59	Integer	R/W	1
t03 Def. 3 hr.	1203	0	0	23	Integer	R/W	1
t13 Def. 3 min.	1213	0	0	59	Integer	R/W	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
t04 Def. 4 hr.	1204	0	0	23	Integer	R/W	1
t14 Def. 4 min.	1214	0	0	59	Integer	R/W	1
t05 Def. 5 hr.	1205	0	0	23	Integer	R/W	1
t15 Def. 5 min.	1215	0	0	59	Integer	R/W	1
t06 Def. 6 hr.	1206	0	0	23	Integer	R/W	1
t16 Def. 6 min.	1216	0	0	59	Integer	R/W	1
Fan control							
F01 Fan stop CO	1500	0	0	1	Integer	R/W	1
F02 Fan del. CO	1503	0	0	30	Integer	R/W	1
F04 FanStop temp	1505	500	-500	500	Float	R/W	0.1
Alarm settings							
A03 Alarm delay	10002	30	0	240	Integer	R/W	1
A04 DoorOpen del	10003	60	0	240	Integer	R/W	1
A12 Pulldown del	10018	90	0	240	Integer	R/W	1
A13 HighLim Air	10019	80	-500	500	Float	R/W	0.1
A14 LowLim Air	10020	-300	-500	500	Float	R/W	0.1
A27 Al.Delay DI1	10028	30	0	240	Integer	R/W	1
A28 Al.Delay DI2	10029	30	0	240	Integer	R/W	1
A36 Alarm S4 %	10037	100	0	100	Integer	R/W	1
--- Reset alarm	2046	0	0	1	Boolean	R/W	1
--- EKC Error	2541	0	0	1	Boolean	R	1
HACCP							
h01 HACCP temp °C	2094	1800	-2000	2000	Float	R	0.1
h10 Max temp.	2095	0	-2000	2000	Float	R	0.1
h11 HACCP sensor	2090	0	0	2	Integer	R/W	1
h12 HACCP limit	2091	80	-500	500	Float	R/W	0.1
h13 HACCP delay	2092	30	0	240	Integer	R/W	1
h14 HACCP S4%	2093	100	0	100	Integer	R/W	1
Miscellaneous							
o01 DelayOfOutp.	2000	5	0	600	Integer	R/W	1
o02 DI1 Config.	2001	0	0	11	Integer	R/W	1
o06 SensorConfig	2014	0	0	2	Integer	R/W	1
o37 DI2 Config.	2055	0	0	12	Integer	R/W	1
o46 Case clean	2056	0	0	2	Integer	R/W	1
Service							
u58 Comp1/LLSV	2510	0	0	1	Boolean	R/W	1
u60 Def. relay	2512	0	0	1	Boolean	R/W	1
u59 Fan relay	2511	0	0	1	Boolean	R/W	1
u64 SuctionValve	2585	1	0	1	Boolean	R/W	1
Alarm destinations							
--- EKC error	20000	0	0	1	Boolean	R	1
--- RTC error	20001	0	0	1	Boolean	R	1
--- S3 error	20002	0	0	1	Boolean	R	1
--- S4 error	20003	0	0	1	Boolean	R	1
--- S5 error	20004	0	0	1	Boolean	R	1
--- High t.alarm	20005	0	0	1	Boolean	R	1
--- Low t.alarm	20006	0	0	1	Boolean	R	1
--- HACCP alarm	20007	0	0	1	Boolean	R	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
--- Door alarm	20008	0	0	1	Boolean	R	1
--- DI1 alarm	20009	0	0	1	Boolean	R	1
--- DI2 alarm	20010	0	0	1	Boolean	R	1
--- Max Def.Time	20011	0	0	1	Boolean	R	1
--- Max HoldTime	20012	0	0	1	Boolean	R	1
--- Case clean	20013	0	0	1	Boolean	R	1
--- Standby mode	20014	1	0	1	Boolean	R	1
For DANFOSS only							
--- Appl.mode	2086	4	1	10	Integer	R	1
Module software	60001	0	0	1000	Float	R	0.01
Transceiver type	60006	3	0	1000	Integer	R	1
In All Groups							
r12 Main switch	117	0	-1	1	Integer	R/W	1
--- EKC State	2007	10	0	100	Integer	R	1
u17 Ther. air	2532	249	-2000	2000	Float	R	0.1
u12 S3 air temp.	2530	1200	-2000	2000	Float	R	0.1
u16 S4 air temp.	2531	249	-2000	2000	Float	R	0.1
u09 S5 temp.	1011	1200	-2000	2000	Float	R	0.1
u10 DI1 status	2002	0	0	1	Boolean	R	1
u13 Night Cond.	2533	0	0	1	Boolean	R	1
u37 DI2 status	2556	0	0	1	Boolean	R	1
u56 Display air	2576	249	-2000	2000	Float	R	0.1
u57 Alarm air	2578	249	-2000	2000	Float	R	0.1

Application 5

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
Thermostat control							
--- Cutout °C	100	20	-500	500	Float	R/W	0.1
r01 Differential	101	20	1	200	Float	R/W	0.1
r02 Max cutout °C	102	500	-490	500	Float	R/W	0.1
r03 Min cutout °C	103	-500	-500	490	Float	R/W	0.1
o17 Disp. S4 %	2021	100	0	100	Integer	R/W	1
r04 Disp. Adj. K	104	0	-200	200	Float	R/W	0.1
r05 Temp.unit	105	0	0	1	Integer	R/W	1
r09 Adjust S4	113	0	-100	100	Float	R/W	0.1
r10 Adjust S3	114	0	-100	100	Float	R/W	0.1
r13 Night offset	125	0	-100	100	Float	R/W	0.1
r15 Ther. S4 %	123	100	0	100	Integer	R/W	1
r39 Th. offset	150	0	0	1	Boolean	R/W	1
r40 Th. offset K	151	0	-500	500	Float	R/W	0.1
--- Night setbck	126	0	0	1	Boolean	R/W	1
--- Forced cool.	3044	0	0	1	Boolean	R/W	1
u28 Temp. ref.	2546	20	-2000	2000	Float	R	0.1
Compressor control							
c01 Min. On time	500	0	0	30	Integer	R/W	1
c02 Min.Off time	501	0	0	30	Integer	R/W	1
c05 Step delay	505	5	0	999	Integer	R/W	1
c30 Cmp relay NC	532	0	0	1	Boolean	R/W	1
c70 Ext. Relay	540	1	0	1	Boolean	R/W	1
Defrost control							
--- Def. Start	1013	0	0	1	Boolean	R/W	1
d01 Def. method	1000	2	0	3	Integer	R/W	1
d02 Def.StopTemp	1001	60	0	250	Float	R/W	0.1
d03 Def.Interval	1002	8	0	48	Integer	R/W	1
d04 Max Def.time	1003	45	0	180	Integer	R/W	1
d05 Time stagg.	1004	0	0	240	Integer	R/W	1
d06 DripOff time	1005	0	0	60	Integer	R/W	1
d10 DefStopSens.	1009	0	0	2	Integer	R/W	1
d16 Pump dwn del	1018	0	0	60	Integer	R/W	1
d18 MaxTherRunT.	1020	0	0	48	Integer	R/W	1
d19 CutoutSSDif.	1021	200	0	200	Float	R/W	0.1
--- HoldAfterDef	2022	0	0	1	Boolean	R/W	1
--- DefrostState	1036	0	0	1	Boolean	R	1
o16 MaxHoldTime	2020	20	0	60	Integer	R/W	1
Defrost schedules							
t01 Def. 1 hr.	1201	0	0	23	Integer	R/W	1
t11 Def. 1 min.	1211	0	0	59	Integer	R/W	1
t02 Def. 2 hr.	1202	0	0	23	Integer	R/W	1
t12 Def. 2 min.	1212	0	0	59	Integer	R/W	1
t03 Def. 3 hr.	1203	0	0	23	Integer	R/W	1
t13 Def. 3 min.	1213	0	0	59	Integer	R/W	1
t04 Def. 4 hr.	1204	0	0	23	Integer	R/W	1
t14 Def. 4 min.	1214	0	0	59	Integer	R/W	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
t05 Def. 5 hr.	1205	0	0	23	Integer	R/W	1
t15 Def. 5 min.	1215	0	0	59	Integer	R/W	1
t06 Def. 6 hr.	1206	0	0	23	Integer	R/W	1
t16 Def. 6 min.	1216	0	0	59	Integer	R/W	1
Alarm settings							
A03 Alarm delay	10002	30	0	240	Integer	R/W	1
A04 DoorOpen del	10003	60	0	240	Integer	R/W	1
A12 Pulldown del	10018	90	0	240	Integer	R/W	1
A13 HighLim Air	10019	80	-500	500	Float	R/W	0.1
A14 LowLim Air	10020	-300	-500	500	Float	R/W	0.1
A27 Al.Delay DI1	10028	30	0	240	Integer	R/W	1
A28 Al.Delay DI2	10029	30	0	240	Integer	R/W	1
A36 Alarm S4 %	10037	100	0	100	Integer	R/W	1
--- Reset alarm	2046	0	0	1	Boolean	R/W	1
--- EKC Error	2541	0	0	1	Boolean	R	1
HACCP							
h01 HACCP temp°C	2094	1800	-2000	2000	Float	R	0.1
h10 Max temp.	2095	0	-2000	2000	Float	R	0.1
h11 HACCP sensor	2090	0	0	2	Integer	R/W	1
h12 HACCP limit	2091	80	-500	500	Float	R/W	0.1
h13 HACCP delay	2092	30	0	240	Integer	R/W	1
h14 HACCP S4%	2093	100	0	100	Integer	R/W	1
Miscellaneous							
o01 DelayOfOutp.	2000	5	0	600	Integer	R/W	1
o02 DI1 Config.	2001	0	0	11	Integer	R/W	1
o06 SensorConfig	2014	0	0	2	Integer	R/W	1
o37 DI2 Config.	2055	0	0	12	Integer	R/W	1
o46 Case clean	2056	0	0	2	Integer	R/W	1
Service							
u58 Comp1/LLSV	2510	0	0	1	Boolean	R/W	1
u60 Def. relay	2512	0	0	1	Boolean	R/W	1
u67 Comp2 relay	2588	0	0	1	Boolean	R/W	1
u62 Alarm relay	2583	0	0	1	Boolean	R/W	1
Alarm destinations							
--- EKC error	20000	0	0	1	Boolean	R	1
--- RTC error	20001	0	0	1	Boolean	R	1
--- S3 error	20002	0	0	1	Boolean	R	1
--- S4 error	20003	0	0	1	Boolean	R	1
--- S5 error	20004	0	0	1	Boolean	R	1
--- High t.alarm	20005	0	0	1	Boolean	R	1
--- Low t.alarm	20006	0	0	1	Boolean	R	1
--- HACCP alarm	20007	0	0	1	Boolean	R	1
--- Door alarm	20008	0	0	1	Boolean	R	1
--- DI1 alarm	20009	0	0	1	Boolean	R	1
--- DI2 alarm	20010	0	0	1	Boolean	R	1
--- Max Def.Time	20011	0	0	1	Boolean	R	1
--- Max HoldTime	20012	0	0	1	Boolean	R	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
--- Case clean	20013	0	0	1	Boolean	R	1
--- Standby mode	20014	1	0	1	Boolean	R	1
For DANFOSS only							
--- Appl.mode	2086	5	1	10	Integer	R	1
Module software	60001	0	0	1000	Float	R	0.01
Transceiver type	60006	3	0	1000	Integer	R	1
In All Groups							
r12 Main switch	117	0	-1	1	Integer	R/W	1
--- EKC State	2007	10	0	100	Integer	R	1
u17 Ther. air	2532	249	-2000	2000	Float	R	0.1
u12 S3 air temp.	2530	1200	-2000	2000	Float	R	0.1
u16 S4 air temp.	2531	249	-2000	2000	Float	R	0.1
u09 S5 temp.	1011	1200	-2000	2000	Float	R	0.1
u10 DI1 status	2002	0	0	1	Boolean	R	1
u13 Night Cond.	2533	0	0	1	Boolean	R	1
u37 DI2 status	2556	0	0	1	Boolean	R	1
u56 Display air	2576	249	-2000	2000	Float	R	0.1
u57 Alarm air	2578	249	-2000	2000	Float	R	0.1

Application 6

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
Thermostat control							
--- Cutout °C	100	20	-500	500	Float	R/W	0.1
r01 Differential	101	20	1	200	Float	R/W	0.1
r02 Max cutout °C	102	500	-490	500	Float	R/W	0.1
r03 Min cutout °C	103	-500	-500	490	Float	R/W	0.1
o17 Disp. S4 %	2021	100	0	100	Integer	R/W	1
r04 Disp. Adj. K	104	0	-200	200	Float	R/W	0.1
r05 Temp.unit	105	0	0	1	Integer	R/W	1
r09 Adjust S4	113	0	-100	100	Float	R/W	0.1
r10 Adjust S3	114	0	-100	100	Float	R/W	0.1
r13 Night offset	125	0	-100	100	Float	R/W	0.1
r15 Ther. S4 %	123	100	0	100	Integer	R/W	1
r39 Th. offset	150	0	0	1	Boolean	R/W	1
r40 Th. offset K	151	0	-500	500	Float	R/W	0.1
--- Night setbck	126	0	0	1	Boolean	R/W	1
--- Forced cool.	3044	0	0	1	Boolean	R/W	1
u28 Temp. ref.	2546	20	-2000	2000	Float	R	0.1
Compressor control							
c01 Min. On time	500	0	0	30	Integer	R/W	1
c02 Min.Off time	501	0	0	30	Integer	R/W	1
c05 Step delay	505	5	0	999	Integer	R/W	1
c30 Cmp relay NC	532	0	0	1	Boolean	R/W	1
c70 Ext. Relay	540	1	0	1	Boolean	R/W	1
Defrost control							
--- Def. Start	1013	0	0	1	Boolean	R/W	1
d01 Def. method	1000	2	0	3	Integer	R/W	1
d02 Def.StopTemp	1001	60	0	250	Float	R/W	0.1
d03 Def.Interval	1002	8	0	48	Integer	R/W	1
d04 Max Def.time	1003	45	0	180	Integer	R/W	1
d05 Time stagg.	1004	0	0	240	Integer	R/W	1
d06 DripOff time	1005	0	0	60	Integer	R/W	1
d10 DefStopSens.	1009	0	0	2	Integer	R/W	1
d16 Pump dwn del	1018	0	0	60	Integer	R/W	1
d18 MaxTherRunT.	1020	0	0	48	Integer	R/W	1
d19 CutoutSSDif.	1021	200	0	200	Float	R/W	0.1
--- HoldAfterDef	2022	0	0	1	Boolean	R/W	1
--- DefrostState	1036	0	0	1	Boolean	R	1
o16 MaxHoldTime	2020	20	0	60	Integer	R/W	1
Defrost schedules							
t01 Def. 1 hr.	1201	0	0	23	Integer	R/W	1
t11 Def. 1 min.	1211	0	0	59	Integer	R/W	1
t02 Def. 2 hr.	1202	0	0	23	Integer	R/W	1
t12 Def. 2 min.	1212	0	0	59	Integer	R/W	1
t03 Def. 3 hr.	1203	0	0	23	Integer	R/W	1
t13 Def. 3 min.	1213	0	0	59	Integer	R/W	1
t04 Def. 4 hr.	1204	0	0	23	Integer	R/W	1
t14 Def. 4 min.	1214	0	0	59	Integer	R/W	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
t05 Def. 5 hr.	1205	0	0	23	Integer	R/W	1
t15 Def. 5 min.	1215	0	0	59	Integer	R/W	1
t06 Def. 6 hr.	1206	0	0	23	Integer	R/W	1
t16 Def. 6 min.	1216	0	0	59	Integer	R/W	1
Alarm settings							
A03 Alarm delay	10002	30	0	240	Integer	R/W	1
A04 DoorOpen del	10003	60	0	240	Integer	R/W	1
A12 Pulldown del	10018	90	0	240	Integer	R/W	1
A13 HighLim Air	10019	80	-500	500	Float	R/W	0.1
A14 LowLim Air	10020	-300	-500	500	Float	R/W	0.1
A27 Al.Delay DI1	10028	30	0	240	Integer	R/W	1
A28 Al.Delay DI2	10029	30	0	240	Integer	R/W	1
A36 Alarm S4 %	10037	100	0	100	Integer	R/W	1
--- Reset alarm	2046	0	0	1	Boolean	R/W	1
--- EKC Error	2541	0	0	1	Boolean	R	1
HACCP							
h01 HACCP temp°C	2094	1800	-2000	2000	Float	R	0.1
h10 Max temp.	2095	0	-2000	2000	Float	R	0.1
h11 HACCP sensor	2090	0	0	2	Integer	R/W	1
h12 HACCP limit	2091	80	-500	500	Float	R/W	0.1
h13 HACCP delay	2092	30	0	240	Integer	R/W	1
h14 HACCP S4%	2093	100	0	100	Integer	R/W	1
Miscellaneous							
o01 DelayOfOutp.	2000	5	0	600	Integer	R/W	1
o02 DI1 Config.	2001	0	0	11	Integer	R/W	1
o06 SensorConfig	2014	0	0	2	Integer	R/W	1
o37 DI2 Config.	2055	0	0	12	Integer	R/W	1
o38 Light config	2057	1	1	3	Integer	R/W	1
o39 Light remote	2058	0	0	1	Boolean	R/W	1
o46 Case clean	2056	0	0	2	Integer	R/W	1
Service							
u58 Comp1/LLSV	2510	0	0	1	Boolean	R/W	1
u60 Def. relay	2512	0	0	1	Boolean	R/W	1
u67 Comp2 relay	2588	0	0	1	Boolean	R/W	1
u63 Light relay	2584	0	0	1	Boolean	R/W	1
Alarm destinations							
--- EKC error	20000	0	0	1	Boolean	R	1
--- RTC error	20001	0	0	1	Boolean	R	1
--- S3 error	20002	0	0	1	Boolean	R	1
--- S4 error	20003	0	0	1	Boolean	R	1
--- S5 error	20004	0	0	1	Boolean	R	1
--- High t.alarm	20005	0	0	1	Boolean	R	1
--- Low t.alarm	20006	0	0	1	Boolean	R	1
--- HACCP alarm	20007	0	0	1	Boolean	R	1
--- Door alarm	20008	0	0	1	Boolean	R	1
--- DI1 alarm	20009	0	0	1	Boolean	R	1
--- DI2 alarm	20010	0	0	1	Boolean	R	1
--- Max Def.Time	20011	0	0	1	Boolean	R	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
--- Max HoldTime	20012	0	0	1	Boolean	R	1
--- Case clean	20013	0	0	1	Boolean	R	1
--- Standby mode	20014	1	0	1	Boolean	R	1
For DANFOSS only							
--- Appl.mode	2086	6	1	10	Integer	R	1
Module software	60001	0	0	1000	Float	R	0.01
Transceiver type	60006	3	0	1000	Integer	R	1
In All Groups							
r12 Main switch	117	0	-1	1	Integer	R/W	1
--- EKC State	2007	10	0	100	Integer	R	1
u17 Ther. air	2532	248	-2000	2000	Float	R	0.1
u12 S3 air temp.	2530	1200	-2000	2000	Float	R	0.1
u16 S4 air temp.	2531	248	-2000	2000	Float	R	0.1
u09 S5 temp.	1011	1200	-2000	2000	Float	R	0.1
u10 DI1 status	2002	0	0	1	Boolean	R	1
u13 Night Cond.	2533	0	0	1	Boolean	R	1
u37 DI2 status	2556	0	0	1	Boolean	R	1
u56 Display air	2576	248	-2000	2000	Float	R	0.1
u57 Alarm air	2578	248	-2000	2000	Float	R	0.1

Application 7

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
Thermostat control							
--- Cutout °C	100	20	-500	500	Float	R/W	0.1
r01 Differential	101	20	1	200	Float	R/W	0.1
r02 Max cutout °C	102	500	-490	500	Float	R/W	0.1
r03 Min cutout °C	103	-500	-500	490	Float	R/W	0.1
o17 Disp. S4 %	2021	100	0	100	Integer	R/W	1
r04 Disp. Adj. K	104	0	-200	200	Float	R/W	0.1
r05 Temp.unit	105	0	0	1	Integer	R/W	1
r09 Adjust S4	113	0	-100	100	Float	R/W	0.1
r10 Adjust S3	114	0	-100	100	Float	R/W	0.1
r13 Night offset	125	0	-100	100	Float	R/W	0.1
r15 Ther. S4 %	123	100	0	100	Integer	R/W	1
r39 Th. offset	150	0	0	1	Boolean	R/W	1
r40 Th. offset K	151	0	-500	500	Float	R/W	0.1
--- Night setbck	126	0	0	1	Boolean	R/W	1
--- Forced cool.	3044	0	0	1	Boolean	R/W	1
u28 Temp. ref.	2546	20	-2000	2000	Float	R	0.1
Compressor control							
c01 Min. On time	500	0	0	30	Integer	R/W	1
c02 Min.Off time	501	0	0	30	Integer	R/W	1
c05 Step delay	505	5	0	999	Integer	R/W	1
c30 Cmp relay NC	532	0	0	1	Boolean	R/W	1
c70 Ext. Relay	540	1	0	1	Boolean	R/W	1
Defrost control							
--- Def. Start	1013	0	0	1	Boolean	R/W	1
d01 Def. method	1000	2	0	3	Integer	R/W	1
d02 Def.StopTemp	1001	60	0	250	Float	R/W	0.1
d03 Def.Interval	1002	8	0	48	Integer	R/W	1
d04 Max Def.time	1003	45	0	180	Integer	R/W	1
d05 Time stagg.	1004	0	0	240	Integer	R/W	1
d06 DripOff time	1005	0	0	60	Integer	R/W	1
d10 DefStopSens.	1009	0	0	2	Integer	R/W	1
d16 Pump dwn del	1018	0	0	60	Integer	R/W	1
d18 MaxTherRunT.	1020	0	0	48	Integer	R/W	1
d19 CutoutSSDif.	1021	200	0	200	Float	R/W	0.1
--- HoldAfterDef	2022	0	0	1	Boolean	R/W	1
--- DefrostState	1036	0	0	1	Boolean	R	1
o16 MaxHoldTime	2020	20	0	60	Integer	R/W	1
Defrost schedules							
t01 Def. 1 hr.	1201	0	0	23	Integer	R/W	1
t11 Def. 1 min.	1211	0	0	59	Integer	R/W	1
t02 Def. 2 hr.	1202	0	0	23	Integer	R/W	1
t12 Def. 2 min.	1212	0	0	59	Integer	R/W	1
t03 Def. 3 hr.	1203	0	0	23	Integer	R/W	1
t13 Def. 3 min.	1213	0	0	59	Integer	R/W	1
t04 Def. 4 hr.	1204	0	0	23	Integer	R/W	1
t14 Def. 4 min.	1214	0	0	59	Integer	R/W	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
t05 Def. 5 hr.	1205	0	0	23	Integer	R/W	1
t15 Def. 5 min.	1215	0	0	59	Integer	R/W	1
t06 Def. 6 hr.	1206	0	0	23	Integer	R/W	1
t16 Def. 6 min.	1216	0	0	59	Integer	R/W	1
Alarm settings							
A03 Alarm delay	10002	30	0	240	Integer	R/W	1
A04 DoorOpen del	10003	60	0	240	Integer	R/W	1
A12 Pulldown del	10018	90	0	240	Integer	R/W	1
A13 HighLim Air	10019	80	-500	500	Float	R/W	0.1
A14 LowLim Air	10020	-300	-500	500	Float	R/W	0.1
A27 Al.Delay DI1	10028	30	0	240	Integer	R/W	1
A28 Al.Delay DI2	10029	30	0	240	Integer	R/W	1
A36 Alarm S4 %	10037	100	0	100	Integer	R/W	1
--- Reset alarm	2046	0	0	1	Boolean	R/W	1
--- EKC Error	2541	0	0	1	Boolean	R	1
HACCP							
h01 HACCP temp °C	2094	1800	-2000	2000	Float	R	0.1
h10 Max temp.	2095	0	-2000	2000	Float	R	0.1
h11 HACCP sensor	2090	0	0	2	Integer	R/W	1
h12 HACCP limit	2091	80	-500	500	Float	R/W	0.1
h13 HACCP delay	2092	30	0	240	Integer	R/W	1
h14 HACCP S4%	2093	100	0	100	Integer	R/W	1
Miscellaneous							
o01 DelayOfOutp.	2000	5	0	600	Integer	R/W	1
o02 DI1 Config.	2001	0	0	11	Integer	R/W	1
o06 SensorConfig	2014	0	0	2	Integer	R/W	1
o37 DI2 Config.	2055	0	0	12	Integer	R/W	1
o41 Railh.ONday%	2060	100	0	100	Integer	R/W	1
o42 Railh.ONngt%	2061	100	0	100	Integer	R/W	1
o43 Railh.cycle	2062	10	6	60	Integer	R/W	1
o46 Case clean	2056	0	0	2	Integer	R/W	1
Service							
u58 Comp1/LLSV	2510	0	0	1	Boolean	R/W	1
u60 Def. relay	2512	0	0	1	Boolean	R/W	1
u67 Comp2 relay	2588	0	0	1	Boolean	R/W	1
u61 Railh. relay	2579	0	0	1	Boolean	R/W	1
Alarm destinations							
--- EKC error	20000	0	0	1	Boolean	R	1
--- RTC error	20001	0	0	1	Boolean	R	1
--- S3 error	20002	0	0	1	Boolean	R	1
--- S4 error	20003	0	0	1	Boolean	R	1
--- S5 error	20004	0	0	1	Boolean	R	1
--- High t.alarm	20005	0	0	1	Boolean	R	1
--- Low t.alarm	20006	0	0	1	Boolean	R	1
--- HACCP alarm	20007	0	0	1	Boolean	R	1
--- Door alarm	20008	0	0	1	Boolean	R	1
--- DI1 alarm	20009	0	0	1	Boolean	R	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
--- DI2 alarm	20010	0	0	1	Boolean	R	1
--- Max Def.Time	20011	0	0	1	Boolean	R	1
--- Max HoldTime	20012	0	0	1	Boolean	R	1
--- Case clean	20013	0	0	1	Boolean	R	1
--- Standby mode	20014	1	0	1	Boolean	R	1
For DANFOSS only							
--- Appl.mode	2086	7	1	10	Integer	R	1
Module software	60001	0	0	1000	Float	R	0.01
Transceiver type	60006	3	0	1000	Integer	R	1
In All Groups							
r12 Main switch	117	0	-1	1	Integer	R/W	1
--- EKC State	2007	10	0	100	Integer	R	1
u17 Ther. air	2532	248	-2000	2000	Float	R	0.1
u12 S3 air temp.	2530	1200	-2000	2000	Float	R	0.1
u16 S4 air temp.	2531	248	-2000	2000	Float	R	0.1
u09 S5 temp.	1011	1200	-2000	2000	Float	R	0.1
u10 DI1 status	2002	0	0	1	Boolean	R	1
u13 Night Cond.	2533	0	0	1	Boolean	R	1
u37 DI2 status	2556	0	0	1	Boolean	R	1
u56 Display air	2576	248	-2000	2000	Float	R	0.1
u57 Alarm air	2578	248	-2000	2000	Float	R	0.1

Application 8

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
Thermostat control							
--- Cutout °C	100	20	-500	500	Float	R/W	0.1
r01 Differential	101	20	1	200	Float	R/W	0.1
r02 Max cutout °C	102	500	-490	500	Float	R/W	0.1
r03 Min cutout °C	103	-500	-500	490	Float	R/W	0.1
o17 Disp. S4 %	2021	100	0	100	Integer	R/W	1
r04 Disp. Adj. K	104	0	-200	200	Float	R/W	0.1
r05 Temp.unit	105	0	0	1	Integer	R/W	1
r09 Adjust S4	113	0	-100	100	Float	R/W	0.1
r10 Adjust S3	114	0	-100	100	Float	R/W	0.1
r13 Night offset	125	0	-100	100	Float	R/W	0.1
r15 Ther. S4 %	123	100	0	100	Integer	R/W	1
r39 Th. offset	150	0	0	1	Boolean	R/W	1
r40 Th. offset K	151	0	-500	500	Float	R/W	0.1
--- Night setbck	126	0	0	1	Boolean	R/W	1
--- Forced cool.	3044	0	0	1	Boolean	R/W	1
u28 Temp. ref.	2546	20	-2000	2000	Float	R	0.1
Compressor control							
c01 Min. On time	500	0	0	30	Integer	R/W	1
c02 Min.Off time	501	0	0	30	Integer	R/W	1
c30 Cmp relay NC	532	0	0	1	Boolean	R/W	1
c70 Ext. Relay	540	1	0	1	Boolean	R/W	1
Defrost control							
--- Def. Start	1013	0	0	1	Boolean	R/W	1
d01 Def. method	1000	2	0	3	Integer	R/W	1
d02 Def.StopTemp	1001	60	0	250	Float	R/W	0.1
d03 Def.Interval	1002	8	0	48	Integer	R/W	1
d04 Max Def.time	1003	45	0	180	Integer	R/W	1
d05 Time stagg.	1004	0	0	240	Integer	R/W	1
d06 DripOff time	1005	0	0	60	Integer	R/W	1
d10 DefStopSens.	1009	0	0	2	Integer	R/W	1
d16 Pump dwn del	1018	0	0	60	Integer	R/W	1
d18 MaxTherRunT.	1020	0	0	48	Integer	R/W	1
d19 CutoutS5Dif.	1021	200	0	200	Float	R/W	0.1
--- HoldAfterDef	2022	0	0	1	Boolean	R/W	1
--- DefrostState	1036	0	0	1	Boolean	R	1
o16 MaxHoldTime	2020	20	0	60	Integer	R/W	1
Defrost schedules							
t01 Def. 1 hr.	1201	0	0	23	Integer	R/W	1
t11 Def. 1 min.	1211	0	0	59	Integer	R/W	1
t02 Def. 2 hr.	1202	0	0	23	Integer	R/W	1
t12 Def. 2 min.	1212	0	0	59	Integer	R/W	1
t03 Def. 3 hr.	1203	0	0	23	Integer	R/W	1
t13 Def. 3 min.	1213	0	0	59	Integer	R/W	1
t04 Def. 4 hr.	1204	0	0	23	Integer	R/W	1
t14 Def. 4 min.	1214	0	0	59	Integer	R/W	1
t05 Def. 5 hr.	1205	0	0	23	Integer	R/W	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
t15 Def. 5 min.	1215	0	0	59	Integer	R/W	1
t06 Def. 6 hr.	1206	0	0	23	Integer	R/W	1
t16 Def. 6 min.	1216	0	0	59	Integer	R/W	1
Alarm settings							
A03 Alarm delay	10002	30	0	240	Integer	R/W	1
A04 DoorOpen del	10003	60	0	240	Integer	R/W	1
A12 Pulldown del	10018	90	0	240	Integer	R/W	1
A13 HighLim Air	10019	80	-500	500	Float	R/W	0.1
A14 LowLim Air	10020	-300	-500	500	Float	R/W	0.1
A27 Al.Delay DI1	10028	30	0	240	Integer	R/W	1
A28 Al.Delay DI2	10029	30	0	240	Integer	R/W	1
A36 Alarm S4 %	10037	100	0	100	Integer	R/W	1
--- Reset alarm	2046	0	0	1	Boolean	R/W	1
--- EKC Error	2541	0	0	1	Boolean	R	1
HACCP							
h01 HACCP temp °C	2094	1800	-2000	2000	Float	R	0.1
h10 Max temp.	2095	0	-2000	2000	Float	R	0.1
h11 HACCP sensor	2090	0	0	2	Integer	R/W	1
h12 HACCP limit	2091	80	-500	500	Float	R/W	0.1
h13 HACCP delay	2092	30	0	240	Integer	R/W	1
h14 HACCP S4%	2093	100	0	100	Integer	R/W	1
Miscellaneous							
h01 HACCP temp °C	2000	5	0	600	Integer	R/W	1
o02 DI1 Config.	2001	0	0	11	Integer	R/W	1
o06 SensorConfig	2014	0	0	2	Integer	R/W	1
o37 DI2 Config.	2055	0	0	12	Integer	R/W	1
o46 Case clean	2056	0	0	2	Integer	R/W	1
Service							
u58 Comp1/LLSV	2510	0	0	1	Boolean	R/W	1
u60 Def. relay	2512	0	0	1	Boolean	R/W	1
Alarm destinations							
--- EKC error	20000	0	0	1	Boolean	R	1
--- RTC error	20001	0	0	1	Boolean	R	1
--- S3 error	20002	0	0	1	Boolean	R	1
--- S4 error	20003	0	0	1	Boolean	R	1
--- S5 error	20004	0	0	1	Boolean	R	1
--- High t.alarm	20005	0	0	1	Boolean	R	1
--- Low t.alarm	20006	0	0	1	Boolean	R	1
--- HACCP alarm	20007	0	0	1	Boolean	R	1
--- Door alarm	20008	0	0	1	Boolean	R	1
--- DI1 alarm	20009	0	0	1	Boolean	R	1
--- DI2 alarm	20010	0	0	1	Boolean	R	1
--- Max Def.Time	20011	0	0	1	Boolean	R	1
--- Max HoldTime	20012	0	0	1	Boolean	R	1
--- Case clean	20013	0	0	1	Boolean	R	1
--- Standby mode	20014	1	0	1	Boolean	R	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
For DANFOSS only							
--- Appl.mode	2086	8	1	10	Integer	R	1
Module software	60001	0	0	1000	Float	R	0.01
Transceiver type	60006	3	0	1000	Integer	R	1
In All Groups							
r12 Main switch	117	0	-1	1	Integer	R/W	1
--- EKC State	2007	10	0	100	Integer	R	1
u17 Ther. air	2532	248	-2000	2000	Float	R	0.1
u12 S3 air temp.	2530	1200	-2000	2000	Float	R	0.1
u16 S4 air temp.	2531	248	-2000	2000	Float	R	0.1
u09 S5 temp.	1011	1200	-2000	2000	Float	R	0.1
u10 DI1 status	2002	0	0	1	Boolean	R	1
u13 Night Cond.	2533	0	0	1	Boolean	R	1
u37 DI2 status	2556	0	0	1	Boolean	R	1
u56 Display air	2576	248	-2000	2000	Float	R	0.1
u57 Alarm air	2578	248	-2000	2000	Float	R	0.1

Application 9

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
Thermostat control							
--- Cutout °C	100	20	-500	500	Float	R/W	0.1
r01 Differential	101	20	1	200	Float	R/W	0.1
r02 Max cutout °C	102	500	-490	500	Float	R/W	0.1
r03 Min cutout °C	103	-500	-500	490	Float	R/W	0.1
o17 Disp. S4 %	2021	100	0	100	Integer	R/W	1
r04 Disp. Adj. K	104	0	-200	200	Float	R/W	0.1
r05 Temp.unit	105	0	0	1	Integer	R/W	1
r09 Adjust S4	113	0	-100	100	Float	R/W	0.1
r10 Adjust S3	114	0	-100	100	Float	R/W	0.1
r13 Night offset	125	0	-100	100	Float	R/W	0.1
r15 Ther. S4 %	123	100	0	100	Integer	R/W	1
r36 HeatStartRel	149	-150	-150	-30	Float	R/W	0.1
r39 Th. offset	150	0	0	1	Boolean	R/W	1
r40 Th. offset K	151	0	-500	500	Float	R/W	0.1
--- Night setbck	126	0	0	1	Boolean	R/W	1
--- Forced cool.	3044	0	0	1	Boolean	R/W	1
u28 Temp. ref.	2546	20	-2000	2000	Float	R	0.1
Compressor control							
c01 Min. On time	500	0	0	30	Integer	R/W	1
c02 Min.Off time	501	0	0	30	Integer	R/W	1
c30 Cmp relay NC	532	0	0	1	Boolean	R/W	1
c70 Ext. Relay	540	1	0	1	Boolean	R/W	1
Defrost control							
--- Def. Start	1013	0	0	1	Boolean	R/W	1
d01 Def. method	1000	2	0	3	Integer	R/W	1
d02 Def.StopTemp	1001	60	0	250	Float	R/W	0.1
d03 Def.Interval	1002	8	0	48	Integer	R/W	1
d04 Max Def.time	1003	45	0	180	Integer	R/W	1
d05 Time stagg.	1004	0	0	240	Integer	R/W	1
d06 DripOff time	1005	0	0	60	Integer	R/W	1
d07 FanStartDel	1007	0	0	60	Integer	R/W	1
d08 FanStartTemp	1006	-50	-150	0	Float	R/W	0.1
d09 FanDuringDef	1008	1	0	2	Integer	R/W	1
d10 DefStopSens.	1009	0	0	2	Integer	R/W	1
d16 Pump dwn del	1018	0	0	60	Integer	R/W	1
d18 MaxTherRunT.	1020	0	0	48	Integer	R/W	1
d19 CutoutSSDif.	1021	200	0	200	Float	R/W	0.1
--- HoldAfterDef	2022	0	0	1	Boolean	R/W	1
--- DefrostState	1036	0	0	1	Boolean	R	1
o16 MaxHoldTime	2020	20	0	60	Integer	R/W	1
Defrost schedules							
t01 Def. 1 hr.	1201	0	0	23	Integer	R/W	1
t11 Def. 1 min.	1211	0	0	59	Integer	R/W	1
t02 Def. 2 hr.	1202	0	0	23	Integer	R/W	1
t12 Def. 2 min.	1212	0	0	59	Integer	R/W	1
t03 Def. 3 hr.	1203	0	0	23	Integer	R/W	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
t13 Def. 3 min.	1213	0	0	59	Integer	R/W	1
t04 Def. 4 hr.	1204	0	0	23	Integer	R/W	1
t14 Def. 4 min.	1214	0	0	59	Integer	R/W	1
t05 Def. 5 hr.	1205	0	0	23	Integer	R/W	1
t15 Def. 5 min.	1215	0	0	59	Integer	R/W	1
t06 Def. 6 hr.	1206	0	0	23	Integer	R/W	1
t16 Def. 6 min.	1216	0	0	59	Integer	R/W	1
Fan control							
F01 Fan stop CO	1500	0	0	1	Integer	R/W	1
F02 Fan del. CO	1503	0	0	30	Integer	R/W	1
F04 FanStop temp	1505	500	-500	500	Float	R/W	0.1
Alarm settings							
A03 Alarm delay	10002	30	0	240	Integer	R/W	1
A04 DoorOpen del	10003	60	0	240	Integer	R/W	1
A12 Pulldown del	10018	90	0	240	Integer	R/W	1
A13 HighLim Air	10019	80	-500	500	Float	R/W	0.1
A14 LowLim Air	10020	-300	-500	500	Float	R/W	0.1
A27 Al.Delay DI1	10028	30	0	240	Integer	R/W	1
A28 Al.Delay DI2	10029	30	0	240	Integer	R/W	1
A36 Alarm S4 %	10037	100	0	100	Integer	R/W	1
--- Reset alarm	2046	0	0	1	Boolean	R/W	1
--- EKC Error	2541	0	0	1	Boolean	R	1
HACCP							
h01 HACCP temp °C	2094	1800	-2000	2000	Float	R	0.1
h10 Max temp.	2095	0	-2000	2000	Float	R	0.1
h11 HACCP sensor	2090	0	0	2	Integer	R/W	1
h12 HACCP limit	2091	80	-500	500	Float	R/W	0.1
h13 HACCP delay	2092	30	0	240	Integer	R/W	1
h14 HACCP S4%	2093	100	0	100	Integer	R/W	1
Miscellaneous							
o01 DelayOfOutp.	2000	5	0	600	Integer	R/W	1
o02 DI1 Config.	2001	0	0	11	Integer	R/W	1
o06 SensorConfig	2014	0	0	2	Integer	R/W	1
o37 DI2 Config.	2055	0	0	12	Integer	R/W	1
o46 Case clean	2056	0	0	2	Integer	R/W	1
Service							
u58 Comp1/LLSV	2510	0	0	1	Boolean	R/W	1
u60 Def. relay	2512	0	0	1	Boolean	R/W	1
u59 Fan relay	2511	0	0	1	Boolean	R/W	1
u62 Alarm relay	2583	0	0	1	Boolean	R/W	1
Alarm destinations							
--- EKC error	20000	0	0	1	Boolean	R	1
--- RTC error	20001	0	0	1	Boolean	R	1
--- S3 error	20002	0	0	1	Boolean	R	1
--- S4 error	20003	0	0	1	Boolean	R	1
--- S5 error	20004	0	0	1	Boolean	R	1
--- High t.alarm	20005	0	0	1	Boolean	R	1
--- Low t.alarm	20006	0	0	1	Boolean	R	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
--- HACCP alarm	20007	0	0	1	Boolean	R	1
--- Door alarm	20008	0	0	1	Boolean	R	1
--- DI1 alarm	20009	0	0	1	Boolean	R	1
--- DI2 alarm	20010	0	0	1	Boolean	R	1
--- Max Def.Time	20011	0	0	1	Boolean	R	1
--- Max HoldTime	20012	0	0	1	Boolean	R	1
--- Case clean	20013	0	0	1	Boolean	R	1
--- Standby mode	20014	1	0	1	Boolean	R	1
For DANFOSS only							
--- Appl.mode	2086	9	1	10	Integer	R	1
Module software	60001	0	0	1000	Float	R	0.01
Transceiver type	60006	3	0	1000	Integer	R	1
In All Groups							
r12 Main switch	117	0	-1	1	Integer	R/W	1
--- EKC State	2007	10	0	100	Integer	R	1
u17 Ther. air	2532	248	-2000	2000	Float	R	0.1
u12 S3 air temp.	2530	1200	-2000	2000	Float	R	0.1
u16 S4 air temp.	2531	248	-2000	2000	Float	R	0.1
u09 S5 temp.	1011	1200	-2000	2000	Float	R	0.1
u10 DI1 status	2002	0	0	1	Boolean	R	1
u13 Night Cond.	2533	0	0	1	Boolean	R	1
u37 DI2 status	2556	0	0	1	Boolean	R	1
u56 Display air	2576	248	-2000	2000	Float	R	0.1
u57 Alarm air	2578	248	-2000	2000	Float	R	0.1

Application 10

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
Thermostat control							
--- Cutout °C	100	20	-500	500	Float	R/W	0.1
r01 Differential	101	20	1	200	Float	R/W	0.1
r02 Max cutout °C	102	500	-490	500	Float	R/W	0.1
r03 Min cutout °C	103	-500	-500	490	Float	R/W	0.1
o17 Disp. S4 %	2021	100	0	100	Integer	R/W	1
r04 Disp. Adj. K	104	0	-200	200	Float	R/W	0.1
r05 Temp.unit	105	0	0	1	Integer	R/W	1
r09 Adjust S4	113	0	-100	100	Float	R/W	0.1
r10 Adjust S3	114	0	-100	100	Float	R/W	0.1
r13 Night offset	125	0	-100	100	Float	R/W	0.1
r15 Ther. S4 %	123	100	0	100	Integer	R/W	1
r39 Th. offset	150	0	0	1	Boolean	R/W	1
r40 Th. offset K	151	0	-500	500	Float	R/W	0.1
--- Night setbck	126	0	0	1	Boolean	R/W	1
--- Forced cool.	3044	0	0	1	Boolean	R/W	1
u28 Temp. ref.	2546	20	-2000	2000	Float	R	0.1
Compressor control							
c01 Min. On time	500	0	0	30	Integer	R/W	1
c02 Min.Off time	501	0	0	30	Integer	R/W	1
c05 Step delay	505	5	0	999	Integer	R/W	1
c30 Cmp relay NC	532	0	0	1	Boolean	R/W	1
c70 Ext. Relay	540	1	0	1	Boolean	R/W	1
Defrost control							
--- Def. Start	1013	0	0	1	Boolean	R/W	1
d01 Def. method	1000	2	0	3	Integer	R/W	1
d02 Def.StopTemp	1001	60	0	250	Float	R/W	0.1
d03 Def.Interval	1002	8	0	48	Integer	R/W	1
d04 Max Def.time	1003	45	0	180	Integer	R/W	1
d05 Time stagg.	1004	0	0	240	Integer	R/W	1
d06 DripOff time	1005	0	0	60	Integer	R/W	1
d07 FanStartDel	1007	0	0	60	Integer	R/W	1
d08 FanStartTemp	1006	-50	-150	0	Float	R/W	0.1
d09 FanDuringDef	1008	1	0	2	Integer	R/W	1
d10 DefStopSens.	1009	0	0	2	Integer	R/W	1
d16 Pump dwn del	1018	0	0	60	Integer	R/W	1
d18 MaxTherRunT.	1020	0	0	48	Integer	R/W	1
d19 CutoutSSDif.	1021	200	0	200	Float	R/W	0.1
--- HoldAfterDef	2022	0	0	1	Boolean	R/W	1
--- DefrostState	1036	0	0	1	Boolean	R	1
o16 MaxHoldTime	2020	20	0	60	Integer	R/W	1
Defrost schedules							
t01 Def. 1 hr.	1201	0	0	23	Integer	R/W	1
t11 Def. 1 min.	1211	0	0	59	Integer	R/W	1
t02 Def. 2 hr.	1202	0	0	23	Integer	R/W	1
t12 Def. 2 min.	1212	0	0	59	Integer	R/W	1
t03 Def. 3 hr.	1203	0	0	23	Integer	R/W	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
t13 Def. 3 min.	1213	0	0	59	Integer	R/W	1
t04 Def. 4 hr.	1204	0	0	23	Integer	R/W	1
t14 Def. 4 min.	1214	0	0	59	Integer	R/W	1
t05 Def. 5 hr.	1205	0	0	23	Integer	R/W	1
t15 Def. 5 min.	1215	0	0	59	Integer	R/W	1
t06 Def. 6 hr.	1206	0	0	23	Integer	R/W	1
t16 Def. 6 min.	1216	0	0	59	Integer	R/W	1
Fan control							
F01 Fan stop CO	1500	0	0	1	Integer	R/W	1
F02 Fan del. CO	1503	0	0	30	Integer	R/W	1
F04 FanStop temp	1505	500	-500	500	Float	R/W	0.1
Alarm settings							
A03 Alarm delay	10002	30	0	240	Integer	R/W	1
A04 DoorOpen del	10003	60	0	240	Integer	R/W	1
A12 Pulldown del	10018	90	0	240	Integer	R/W	1
A13 HighLim Air	10019	80	-500	500	Float	R/W	0.1
A14 LowLim Air	10020	-300	-500	500	Float	R/W	0.1
A27 Al.Delay DI1	10028	30	0	240	Integer	R/W	1
A28 Al.Delay DI2	10029	30	0	240	Integer	R/W	1
A36 Alarm S4 %	10037	100	0	100	Integer	R/W	1
--- Reset alarm	2046	0	0	1	Boolean	R/W	1
--- EKC Error	2541	0	0	1	Boolean	R	1
HACCP							
h01 HACCP temp°C	2094	1800	-2000	2000	Float	R	0.1
h10 Max temp.	2095	0	-2000	2000	Float	R	0.1
h11 HACCP sensor	2090	0	0	2	Integer	R/W	1
h12 HACCP limit	2091	80	-500	500	Float	R/W	0.1
h13 HACCP delay	2092	30	0	240	Integer	R/W	1
h14 HACCP S4%	2093	100	0	100	Integer	R/W	1
Miscellaneous							
o01 DelayOfOutp.	2000	5	0	600	Integer	R/W	1
o02 DI1 Config.	2001	0	0	11	Integer	R/W	1
o06 SensorConfig	2014	0	0	2	Integer	R/W	1
o37 DI2 Config.	2055	0	0	12	Integer	R/W	1
o46 Case clean	2056	0	0	2	Integer	R/W	1
Service							
u58 Comp1/LLSV	2510	0	0	1	Boolean	R/W	1
u60 Def. relay	2512	0	0	1	Boolean	R/W	1
u59 Fan relay	2511	0	0	1	Boolean	R/W	1
u67 Comp2 relay	2588	0	0	1	Boolean	R/W	1
Alarm destinations							
--- EKC error	20000	0	0	1	Boolean	R	1
--- RTC error	20001	0	0	1	Boolean	R	1
--- S3 error	20002	0	0	1	Boolean	R	1
--- S4 error	20003	0	0	1	Boolean	R	1
--- S5 error	20004	0	0	1	Boolean	R	1
--- High t.alarm	20005	0	0	1	Boolean	R	1
--- Low t.alarm	20006	0	0	1	Boolean	R	1

Parameter	PNU	Value	Min.	Max.	Type	RW	Scale
--- HACCP alarm	20007	0	0	1	Boolean	R	1
--- Door alarm	20008	0	0	1	Boolean	R	1
--- DI1 alarm	20009	0	0	1	Boolean	R	1
--- DI2 alarm	20010	0	0	1	Boolean	R	1
--- Max Def.Time	20011	0	0	1	Boolean	R	1
--- Max HoldTime	20012	0	0	1	Boolean	R	1
--- Case clean	20013	0	0	1	Boolean	R	1
--- Standby mode	20014	1	0	1	Boolean	R	1
For DANFOSS only							
--- Appl.mode	2086	10	1	10	Integer	R	1
Module software	60001	0	0	1000	Float	R	0.01
Transceiver type	60006	3	0	1000	Integer	R	1
In All Groups							
r12 Main switch	117	0	-1	1	Integer	R/W	1
--- EKC State	2007	10	0	100	Integer	R	1
u17 Ther. air	2532	248	-2000	2000	Float	R	0.1
u12 S3 air temp.	2530	1200	-2000	2000	Float	R	0.1
u16 S4 air temp.	2531	248	-2000	2000	Float	R	0.1
u09 S5 temp.	1011	1200	-2000	2000	Float	R	0.1
u10 DI1 status	2002	0	0	1	Boolean	R	1
u13 Night Cond.	2533	0	0	1	Boolean	R	1
u37 DI2 status	2556	0	0	1	Boolean	R	1
u56 Display air	2576	248	-2000	2000	Float	R	0.1
u57 Alarm air	2578	248	-2000	2000	Float	R	0.1

Danfoss A/S

Climate Solutions • danfoss.com • +45 7488 2222

Any information, including, but not limited to information on selection of product, its application or use, product design, weight, dimensions, capacity or any other technical data in product manuals, catalogues, descriptions, advertisements, etc. and whether made available in writing, orally, electronically, online or via download, shall be considered informative, and is only binding if and to the extent, explicit reference is made in a quotation or order confirmation. Danfoss cannot accept any responsibility for possible errors in catalogues, brochures, videos and other material. Danfoss reserves the right to alter its products without notice. This also applies to products ordered but not delivered provided that such alterations can be made without changes to form, fit or function of the product.

All trademarks in this material are property of Danfoss A/S or Danfoss group companies. Danfoss and the Danfoss logo are trademarks of Danfoss A/S. All rights reserved.