

Installation Instructions

LOP Connection and Set-up VLT® DriveMotor FCP/FCM 106

Items Supplied

- Local operating panel (LOP), 175N0128 IP65, see *Illustration 1.1*.
- Fixture for LOP, 175N2717 (included in 175N0128), see Illustration 1.2.
- LOP cable.




Illustration 1.1 Local Operation Panel (LOP) 175N0128 IP65




Illustration 1.2 Fixture for LOP 175N2717 (included in 175N0128)



Safety Instructions

Refer to VLT® DriveMotor FCP 106 and FCM 106 Operating Guide for detailed information about safety precautions for installation.

AWARNING

DISCHARGE TIME

The frequency converter contains DC-link capacitors, which can remain charged even when the frequency converter is not powered. High voltage can be present even when the warning LED indicator lights are off. Failure to wait the specified time after power has been removed before performing service or repair work can result in death or serious injury.

- 1. Stop the motor.
- Disconnect AC mains, permanent magnet type motors, and remote DC-link supplies, including battery back-ups, UPS, and DC-link connections to other frequency converters.
- 3. Wait for the capacitors to discharge fully, before performing any service or repair work. The waiting time is specified in *Table 1.1*.

Voltage [V]	Power range ¹⁾ [kW (hp)]	Minimum waiting time (minutes)
3x400	0.55-7.5 (0.75-10)	4

Table 1.1 Discharge Time

1) Power ratings relate to NO, see VLT® DriveMotor FCP 106 and FCM 106 Operating Guide.

Connection to FCP 106 or FCM 106

- 1. Connect the LOP as shown in *Table 1.2* and *Illustration 1.3*.
- After completing connections, cut off or isolate excess wire.
- 3. Connect terminal 27 to +24 V or set parameter 5-12 Terminal 27 Digital Input to [0] No operation or [1] Reset, see footnote 2 in Table 1.3.

Terminal	Dual-speed	Dual-mode	Dual-direction			
	operation	operation	operation			
18	Purpl	e or orange	Gray			
27	Brown					
29	Green					
12	Red					
50	Yellow					
53	White					
55		Blue				

Table 1.2 Electrical Connections




Illustration 1.3 LOP Connections to FCP 106 or FCM 106



Set-up

- 1. Perform set-up according to *Table 1.3*.
- 2. Use the [+]/[-] keys to set reference.
- 3. At power-up, the unit is always in stop mode. The set reference is stored during power down. To set up permanent start mode, connect terminal 12 to terminal 18 and do not connect purple/orange/gray wire to terminal 18. Permanent start mode disables the stop function on the LOP.

Function	Settings	Key I (Start)	Key II (Start)	O
				Key (Stop)
Default - Dual speed operation	No changes to factory setting.	Run on set	Run on 5 Hz ¹⁾	Stop (and reset ²⁾
(connect purple or orange wire)		reference (+/-)	jog speed	- if trip)
Function 2 - Dual-mode	Select the modes of operation in set-ups 1 and 2.	Run with	Run with	Stop (and reset ²⁾
operation	Set parameter 0-10 Active Set-up to [9] Multi Set-up.	set-up 1	set-up 2	- if trip)
(connect purple or orange wire)	Set parameter 5-13 Terminal 29 Digital Input to [23] Set-up			
	select bit 0.			
Function 3 - Dual direction	Set parameter 4-10 Motor Speed Direction to [2] Both	Run forward	Run reverse	Stop (and reset ²⁾
operation (connect gray wire)	directions.			- if trip)
	Set parameter 5-13 Terminal 29 Digital Input to [11] Start			
	reversing.			

Table 1.3 LOP Operating Mode

- 1) Set jog speed in parameter 3-11 Jog Speed [Hz].
- 2) When reset is required, set parameter 5-12 Terminal 27 Digital Input to [1] Reset.



Danfoss can accept no responsibility for possible errors in catalogues, brochures and other printed material. Danfoss reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without subsequential changes being necessary in specifications already agreed. All trademarks in this material are property of the respective companies. Danfoss and the Danfoss logotype are trademarks of Danfoss A/S. All rights reserved.

Danfoss A/S Ulsnaes 1 DK-6300 Graasten vlt-drives.danfoss.com

