

Danfoss

Heat meter SonoMeter 31

M-bus communication protocol description





Table of contents

1. Reading of integral and moment parameters	3
2. Readout of hours and days archive.....	7
3. Secondary addressing.....	10
4. Reading the relay output parameters	11
5. Setting the relay output parameters	12
6. Reading of meter configuration	12

1. Reading of integral and moment parameters

First is SND_NKE / E5 negotiation is performed. Master sends to the meter:

0	1	2	3	4
10h	40h	A	CS	16h

Answer of the meter:

0
E5h

A – M-bus primary address

CS – control sum

Then the selection of integral and moment parameters is performed. Master sends to the meter:

0	1	2	3	4	5	6	7	8	9
68h	04h	04h	68h	53h	A	50h	00h	CS	16h

Answer of the meter:

0
E5h

Then the query for data is performed. Master sends to the meter:

0	1	2	3	4
10h	5B/7B	A	CS	16

Answer of the meter:

0	1	2	3	4	5	6	7	8	9	10	11	12	13	14
68h	L	L	68h	08h	A	72h	Nr ₀	Nr ₁	Nr ₂	Nr ₃	34h	2Ch	05h	04h
15	16	17	18			19-(n-2)				n-1	n			
Acc	00h	00h	00h			Integral and moment parameters block				CS	16h			

7...10 bytes: „Nr₀... Nr₃“ – Serial number of meter,

11, 12 bytes: „34h,2Ch“ – Manufacturer code (AXI)

13 byte: „05h“ – Number of M-bus protocol version (3)

14 byte: „04h“ – Measured medium („Heat“)

In the block of integral moment parameters can be following parameters (depending on configuration of the meter):

1. **Energy (total)** (except scheme F1 and F2).
2. **Energy 1** (only for schemes U1L, U2L, A, AC, A1, A1C, A2, A4, U1A3 and U2A3).
3. **Energy 2** (only for schemes U1L, U2L, A, AC, A1, A1C, A2, A4, U1A3 and U2A3).
4. **Volume (or mass) 1.**
5. **Volume (or mass) 2** (only for schemes U1F, U2F, A, AC, A1, A1C, A2, A4, A5, U1A3, U2A3 and F2).

6. **Volume (or mass) -2** (only for schemes A, AC, A1, A1C, when algorythm 3 is selected).
7. **Volume (or mass) 3** (when flow input 3 is active).
8. **Volume (or mass) 4** (when flow input 4 is active).
9. **Power** (except schemes F1 and F2).
10. **Flow 1**
11. **Flow 2** (only for schemes U1F, U2F, A, AC, A1, A1C, A2, A4, A5, U1A3, U2A3 and F2).
12. **Flow 3** (when flow input 3 is active).
13. **Flow 4** (when flow input 4 is active).
14. **Temperature 1** (when temperature input 1 is active).
15. **Temperature 2** (when temperature input 2 is active).
16. **Temperature 3** (when temperature input 3 is active).
17. **Temperature 4 (cold water temperature)** (only for schemes AC, A1C, A3, U1A3, U2A3).
18. **Pressure 1** (when pressure input 1 is active).
19. **Pressure 2** (when pressure input 2 is active).

Also, independently of configuration, following parameters are in the block:

1. **Current date/time** of the meter
2. **Error codes**
3. **Power supply duration**
4. **Normal working time**
5. **Additional control sum** (CRC-16)

Coding of parameters

Energy

Parameter	DIF	VIF								Data
		0,1 MWh	0,1 GJ	0,01 MWh	0,01 GJ	0,001 MWh	0,001 GJ	0,0001 MWh	0,0001 GJ	
Energy (total)	04	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)
Energy 1	84 40	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)
Energy 2	84 80 40	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)

Volume (or mass)

Parameter	DIF	VIF								Data
		1 m ³	1 t	0,1 m ³	0,1 t	0,01 m ³	0,01 t	0,001 m ³	0,001 t	
Volume (mass) 1	04	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) 2	84 40	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) 3	84 80 40	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) 4	84 C0 40	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) -2	84 80 80 40	16	96	15	95	14	94	13	93	4 bytes (long)

Power

Parameter	DIF	VIF	Data
Power	05	2E	4 bytes (float) kW

Flow

Parameter	DIF	VIF (m³/h)	VIF (t/h)	Data
Flow 1	05	3E	3E	4 bytes (float)
Flow 2	85 40	3E	3E	4 bytes (float)
Flow 3	85 80 40	3E	3E	4 bytes (float)
Flow 4	85 C0 40	3E	3E	4 bytes (float)

Temperature

Parametras	DIF	VIF	Data
Temperature 1	02	59	2 bytes (word), 0,01°C
Temperature 2	02	5D	2 bytes (word), 0,01°C
Temperature 3	82 40	59	2 bytes (word), 0,01°C
Temperature 4 (const.)	82 40	65	2 bytes (word), 0,01°C

Pressure

Parametras	DIF	VIF	Data
Pressure 1	03	68	3 bytes (word) 0,1 kPa
Pressure 2	83 40	68	3 bytes (word) 0,1 kPa

Current date/time

Parameter	DIF	VIF	Data
Date/time	44	6D	4 bytes (date/time format)

Format of date/time is following:

Bytes			
3	2	1	0
Bits			
31 30 29 28 27 26 25 24 23 22 21 20 19 18 17 16 15 14 13 12 11 10 09 08 07 06 05 04 03 02 01 00			
Year ₁	Month	Year ₀	Day
			0 0 0
			Hour Minutes

Minutes - <0 to 59>

Hour - <0 to 23>

Day - <1 to 31>

Month - <1 to 12>

Year=Year₁|Year₀ (Year₀ – low significant part, Year₁ – high significant part) <0 to 99>

Error codes

Parameter	DIF	VIF	Er1 (2 bytes)		Er2 (4 bytes)					
Error code	06	FD 17	B1	B2	B3	B4	B5	B6		

Format of error code **Er1 (Er1: FEDCBA)** is following:

Byte B2																Byte B1															
Bits																Digits and bits (3 2 1 0) of error code															
F	E	D	C	B	A	0	3	2	1	3	2	1	2	1	0	2	1	0	2	1	0	2	1	0	2	1	0	2	1	0	

Format of error code **Er2 (Er2: EDCBA)** is following:

Byte B4																Byte B3															
Bits																Digits of error code															
D	C	B	A	0	3	2	1	0	3	2	1	0	2	1	0	2	1	0	2	1	0	2	1	0	2	1	0	2	1	0	
Byte B6																Byte B5															
Bits																Digits of error code															
Not used																E															

Power supply duration

Parameter	DIF	VIF	Data
Power supply duration	04	20	4 bytes (long integer, time in seconds)

Normal working time

Parameter	DIF	VIF	Data
Normal working time	04	24	4 bytes (long integer, time in seconds)

Additional control sum (CRC-16)

Parameter	DIF	VIF	Data
Additional control sum (CRC-16)	02	7F	2 bytes

2. Readout of hours and days archive

First is SND_NKE / E5 negotiation is performed. Master sends to the meter:

0	1	2	3	4
10h	40h	A	CS	16h

Answer of the meter:

0
E5h

Selection of hours or days archive is performed. Master sends to the meter:

0	1	2	3	4	5	6	7	8	9
68h	04h	04h	68h	53h	A	50h	04h – for hours archive 03h – for days archive	CS	16h

Answer of the meter:

0
E5h

Then the query for data is performed. Master sends to the meter:

0	1	2	3	4
10h	5B/7B	A	CS	16

Answer of the meter:

0	1	2	3	4	5	6	7	8	9	10	11	12	13	14
68h	L	L	68h	08h	A	72h	Nr ₀	Nr ₁	Nr ₂	Nr ₃	34h	2Ch	05h	04h
19-(n-2)														
Acc	00h	00h	00h	Hours/days archive record block								CS	16h	

The readout of the next record of the archive is performed by sending data query packet with changed 1st byte 5Bh/7Bh (toggling the most significant bit of the byte). Archive readout is performed from the newest records.

In the first block of hours and days archive can be following parameters (depending on meter configuration):

1. **Energy (total)** (except scheme F1 and F2).
2. **Energy 1** (only for schemes U1L, U2L, A, AC, A1, A1C, A2, A4, U1A3 and U2A3).
3. **Energy 2** (only for schemes U1L, U2L, A, AC, A1, A1C, A2, A4, U1A3 and U2A3).
4. **Volume (or mass) 1**.
5. **Volume (or mass) 2** (only for schemes U1F, U2F, A, AC, A1, A1C, A2, A4, A5, U1A3, U2A3 and F2).
6. **Volume (or mass) -2** (only for schemes A, AC, A1, A1C, when algorythm 3 is selected).
7. **Volume (or mass) 3** (when flow input 3 is active).
8. **Volume (or mass) 4** (when flow input 4 is active).
9. **Power** (except schemes F1 and F2).
10. **Temperature 1 (average)** (when temperature input 1 is active).
11. **Temperature 2 (average)** (when temperature input 2 is active).
12. **Temperature 3 (average)** (when temperature input 3 is active).
13. **Temperature 4 (average of cold water temperature)** (only for schemes AC, A1C, A3, U1A3, U2A3).
14. **Pressure 1 (average)** (when pressure input 1 is active).
15. **Pressure 2 (average)** (when pressure input 2 is active).

Also, independently of configuration, following parameters are in the block:

- 1. Current date/time** of the meter
- 2. Error codes**
- 3. Power supply duration**
- 4. Normal working time**
- 5. Additional control sum (CRC-16)**

In second block can be following parameters (depending on meter configuration):

- 1. Duration, when temperature difference (T1-T2) < (T1-T2)min.**
- 2. Duration, when flow q1 < q1min.**
- 3. Duration, when flow q2 < q2min.**
- 4. Duration, when flow q3 < q3min.**
- 5. Duration, when flow q4 < q4min.**
- 6. Duration, when flow q1 > q1max.**
- 7. Duration, when flow q2 > q2max.**
- 8. Duration, when flow q3 > q3max.**
- 9. Duration, when flow q4 > q4max.**
- 10. Duration of error of flow sensor 1**
- 11. Duration of error of flow sensor 2**
- 12. Duration of error of flow sensor 3**
- 13. Duration of error of flow sensor 4**
- 14. Additional control sum (CRC-16)**

Coding of parameters

Energy

Parameter	DIF	VIF								Data
		0,1 MWh	0,1 GJ	0,001 MWh	0,001 GJ	0,0001 MWh	0,0001 GJ	0,00001 MWh	0,00001 GJ	
Energy (total)	04	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)
Energy 1	84 40	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)
Energy 2	84 80 40	FB 00	FB 08	07	0F	06	0E	05	0D	4 bytes (long)

Volume (or mass)

Parameter	DIF	VIF								Data
		1 m³	1 t	0,1 m³	0,1 t	0,01 m³	0,01 t	0,001 m³	0,001 t	
Volume (mass) 1	04	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) 2	84 40	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) 3	84 80 40	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) 4	84 C0 40	16	96	15	95	14	94	13	93	4 bytes (long)
Volume (mass) -2	84 80 80 40	16	96	15	95	14	94	13	93	4 bytes (long)

Temperature (average)

Parametras	DIF	VIF	Data
Temperature 1	02	59	2 bytes (word), 0,01°C
Temperature 2	02	5D	2 bytes (word), 0,01°C
Temperature 3	82 40	59	2 bytes (word), 0,01°C
Temperature 4 (const.)	82 40	65	2 bytes (word), 0,01°C

Pressure (average)

Parametras	DIF	VIF	Data
Pressure 1	03	68	3 bytes (word) 0,1 kPa
Pressure 2	83 40	68	3 bytes (word) 0,1 kPa

Date and time of records

Parameter	DIF	VIF	Data
Date/time	44	6D	4 bytes (date/time format)

Format of date/time is following:

Bytes															
3				2				1				0			
Bits															
31	30	29	28	27	26	25	24	23	22	21	20	19	18	17	16
Year ₁	Month	Year ₀	Day	0	0	0	0	0	0	0	0	0	0	0	0
Minutes - <0 to 59>				Hour - <0 to 23>				Day - <1 to 31>				Month - <1 to 12>			
Year=Year ₁ Year ₀ (Year ₀ – low significant part, Year ₁ – high significant part) <0 to 99>															

Minutes - <0 to 59>

Hour - <0 to 23>

Day - <1 to 31>

Month - <1 to 12>

Year=Year₁|Year₀ (Year₀ – low significant part, Year₁ – high significant part) <0 to 99>

Error codes

Parameter	DIF	VIF	Er1 (2 bytes)	Er2 (4 bytes)					
Error code	06	FD 17	B1 B2	B3	B4	B5	B6		

Format of error code **Er1 (Er1: FEDCBA)** is following:

Byte B2																Byte B1							
Bits																Digits and bits (3 2 1 0) of error code							
07	06	05	04	03	02	01	00	07	06	05	04	03	02	01	00	F	E	D	C	B	A		
0	3	2	1	3	2	1	2	1	0	2	1	0	2	1	0	2	1	0	2	1	0		

Format of error code **Er2 (Er2: EDCBA)** is following:

Byte B4																Byte B3							
Bits																Digits of error code							
07	06	05	04	03	02	01	00	07	06	05	04	03	02	01	00	D	C	B	A				
0	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00								

Byte B6																Byte B5							
Bits																Digits of error code							
15	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00								
15	14	13	12	11	10	09	08	07	06	05	04	03	02	01	00								
Not used																E							

Power supply duration

Parameter	DIF	VIF	Data
Power supply duration	04	20	4 bytes (long integer, time in seconds)

Normal working time

Parameter	DIF	VIF	Data
Normal working time	04	24	4 bytes (long integer, time in seconds)

Additional control sum (CRC-16)

Parameter	DIF	VIF	Data
Additional control sum (CRC-16)	02	7F	2 bytes

Duration of errors

Parameter	DIF	VIF	Data
Duration, when temperature difference (T1-T2) < (T1-T2)min	04	74	4 bytes (long integer, time in seconds)
Duration, when flow q1 < q1min	84 40	74	4 bytes (long integer, time in seconds)
Duration, when flow q2 < q2min	84 80 40	74	4 bytes (long integer, time in seconds)
Duration, when flow q3 < q3min	84 C0 40	74	4 bytes (long integer, time in seconds)
Duration, when flow q4 < q4min	84 80 80 40	74	4 bytes (long integer, time in seconds)
Duration, when flow q1 > q1max	84 C0 80 40	74	4 bytes (long integer, time in seconds)
Duration, when flow q2 > q2max	84 80 C0 40	74	4 bytes (long integer, time in seconds)
Duration, when flow q3 > q3max	84 C0 C0 40	74	4 bytes (long integer, time in seconds)
Duration, when flow q4 > q4max	84 80 80 80 40	74	4 bytes (long integer, time in seconds)
Duration of error of flow sensor 1	84 C0 80 80 40	74	4 bytes (long integer, time in seconds)
Duration of error of flow sensor 2	84 80 C0 80 40	74	4 bytes (long integer, time in seconds)
Duration of error of flow sensor 3	84 C0 C0 80 40	74	4 bytes (long integer, time in seconds)
Duration of error of flow sensor 4	84 80 80 C0 40	74	4 bytes (long integer, time in seconds)

3. Secondary addressing

Meter supports secondary addressing. The address of secondary addressing is meter parameter "Serial number" (Nr), and most significant digit (7-th) of address splits meter in to 1 ... 7 sub-meters.

Possible meter response telegrams, depending on the address code, secondary address type meter configuration code bits (B0.. B7) and meter configuration, see on the table:

Adress	Transmitted data	Conditions
{Nr}	As primary addressing case (see chapter 1)	B0=1 (or all B0,B1...B7=0) (standard settings)
{1000000+Nr}	Transmitted parameters E ₁ , V ₂ (or M ₂), q ₂ , T ₃ , p ₂ , ton, td, coded as E, V(or M), q, T ₁ , p, ton, td	B1=1 and 2 nd flow channel is on
{2000000+Nr}	Transmitted parameters E ₂ , V ₃ , q ₃ , ton, coded as E, V, q, ton	B2=1 and 3 rd flow channel is on
{3000000+Nr}	Transmitted parameters V ₄ , q ₄ , ton, coded as V, q, ton	B3=1 and 4 th flow channel is on
{4000000+Nr}	Days archive	B4=1
{5000000+Nr}	Hours archive	B5=1
{6000000+Nr}	Days archive from end of last month	B6=1
{7000000+Nr}	Hours archive from end of last month	B7=1

Here:

- E – energy
- V – volume (M – mass)
- q – flow
- T – temperature
- p – pressure
- ton – power supply duration
- td – normal working time
- 1...4 – number of channel

4. Reading the relay output parameters

First is SND_NKE / E5 negotiation is performed. Master sends to the meter:

0	1	2	3	4
10h	40h	A	CS	16h

Answer of the meter:

0
E5h

Selection of relay output parameters is performed. Master sends to the meter:

0	1	2	3	4	5	6	7	8	9
68h	04h	04h	68h	53h	A	50h	05h	CS	16h

Answer of the meter:

0
E5h

Then the query for data is performed. Master sends to the meter:

0	1	2	3	4
10h	5B/7B	A	CS	16

Answer of the meter:

0	1	2	3	4	5	6	7	8	9	10	11	12	13	14
68h	21h	21h	68h	08h	A	72h	Nr ₀	Nr ₁	Nr ₂	Nr ₃	34h	2Ch	04h	04h
15	16	17	18	19	20	21	22	23	24	25	26	27	28	29
Acc	00h	00h	00h	0Fh	00h	RelP	00h	Max ₀	Max ₁	Max ₂	Max ₃	Min ₀	Min ₁	Min ₂
31	32	33	34	35	36	37	38							
RegT ₀	RegT ₁	RegL ₀	RegL ₁	RegCS ₀	RegCS ₁	CS	16							

Parameters:

Parameter	Description
RelP	Code of parameter for relay output
Max	Upper value limit of regulated parameter (float)
Min	Lower value limit of regulated parameter (float)
RegT	Integral constant for regulation time (integer, sec)
RegL	Regulated valve run time (integer, sec)
Reg CS	Control sum of parameters RelP...RegL

5. Setting the relay output parameters

Master sends following packet to the meter:

0	1	2	3	4	5	6	7	8	9	10	11	12	13	14
68h	15h	15h	68h	53h	A	51h	0Fh	00h	RelP	00h	Max ₀	Max ₁	Max ₂	Max ₃
15	16	17	18	19	20	21	22	23	24	25	26			
Min ₀	Min ₁	Min ₂	Min ₃	RegT ₀	RegT ₁	RegL ₀	RegL ₁	RegCS ₀	RegCS ₁	CS	16			

Answer of the meter:

0
E5h

Parameters:

Parameter	Description
RelP	Code of parameter for relay output
Max	Upper value limit of regulated parameter (float)
Min	Lower value limit of regulated parameter (float)
RegT	Integral constant for regulation time (integer, sec)
RegL	Regulated valve run time (integer, sec)
Reg CS	Control sum of parameters RelP...RegL

6. Reading of meter configuration

First is SND_NKE / E5 negotiation is performed. Master sends to the meter:

0	1	2	3	4
10h	40h	A	CS	16h

Answer of the meter:

0
E5h

Then the selection of configuration parameters is performed. Master sends to the meter:

0	1	2	3	4	5	6	7	n-1	n
68h	04h	04h	68h	53h	A	50h	06h	CS	16h

Answer of the meter:

0
E5h

Then the query for data is performed. Master sends to the meter:

0	1	2	3	4
10h	5B/7B	A	CS	16

Answer of the meter:

0	1	2	3	4	5	6	7	8	9	10	11	12	13	14
68h	L	L	68h	08h	A	72h	Nr ₀	Nr ₁	Nr ₂	Nr ₃	34h	2Ch	05h	04h
15	16	17	18	19	20	21-(n-2)						n-1	n	
Acc	00h	00h	00h	0Fh	01h	Configuration of the meter						CS	16	

Coding of configuration of the meter:

Offset in bytes	Parameter (format)																																																
0	Nr ₀	Serial number of meter Nr (Unsigned integer)																																															
1	Nr ₁																																																
2	Nr ₂																																																
3	Nr ₃																																																
4	Nr1 ₀	Serial number of 1-st flow sensor Nr1 (Unsigned integer)																																															
5	Nr1 ₁																																																
6	Nr1 ₂																																																
7	Nr1 ₃																																																
8	Nr2 ₀	Serial number of 2-nd flow sensor Nr2 (Unsigned integer)																																															
9	Nr2 ₁																																																
10	Nr2 ₂																																																
11	Nr2 ₃																																																
12	ANr ₀	Customer number (Unsigned integer)																																															
13	ANr ₁																																																
14	ANr ₂																																																
15	ANr ₃																																																
16	BatData ₀	Battery change date (Unsigned integer, seconds since 2004.01.01 00:00)																																															
17	BatData ₁																																																
18	BatData ₀₂																																																
19	BatData ₀₃																																																
20	ModifAlg	Code of scheme and code of algorithm:																																															
		<table border="1"> <thead> <tr> <th colspan="8">Bits</th> </tr> <tr> <th>7</th><th>6</th><th>5</th><th>4</th><th>3</th><th>2</th><th>1</th><th>0</th> </tr> </thead> <tbody> <tr> <td colspan="8">Code of scheme:</td> </tr> <tr> <td colspan="8">0x00 – U1 0x01 – U2 0x03 – U1F 0x04 – U2F 0x05 – U1L 0x06 – U2L 0x07 – U3 0x08 – A 0x09 – A1 0x0A – A1C 0x0B – A2 0x0C – A3 0x0D – A4 0x0E – A5 0x0F – U1A3 0x10 – U2A3 0x11 – F1 0x12 – F2</td> </tr> <tr> <td colspan="8">Code of algorithm</td> </tr> </tbody> </table>								Bits								7	6	5	4	3	2	1	0	Code of scheme:								0x00 – U1 0x01 – U2 0x03 – U1F 0x04 – U2F 0x05 – U1L 0x06 – U2L 0x07 – U3 0x08 – A 0x09 – A1 0x0A – A1C 0x0B – A2 0x0C – A3 0x0D – A4 0x0E – A5 0x0F – U1A3 0x10 – U2A3 0x11 – F1 0x12 – F2								Code of algorithm							
Bits																																																	
7	6	5	4	3	2	1	0																																										
Code of scheme:																																																	
0x00 – U1 0x01 – U2 0x03 – U1F 0x04 – U2F 0x05 – U1L 0x06 – U2L 0x07 – U3 0x08 – A 0x09 – A1 0x0A – A1C 0x0B – A2 0x0C – A3 0x0D – A4 0x0E – A5 0x0F – U1A3 0x10 – U2A3 0x11 – F1 0x12 – F2																																																	
Code of algorithm																																																	
21	TermoTipai	Temperature sensors types and status:																																															
		<table border="1"> <thead> <tr> <th colspan="8">Bits</th> </tr> <tr> <th>7</th><th>6</th><th>5</th><th>4</th><th>3</th><th>2</th><th>1</th><th>0</th> </tr> </thead> <tbody> <tr> <td>Not used</td><td>T3 activation</td><td>T2 activation</td><td>T1 activation</td><td colspan="4">Types: 0 – Pt500 1 – Pt1000 2 – 500Π 3 – 1000Π</td> </tr> </tbody> </table>								Bits								7	6	5	4	3	2	1	0	Not used	T3 activation	T2 activation	T1 activation	Types: 0 – Pt500 1 – Pt1000 2 – 500Π 3 – 1000Π																			
Bits																																																	
7	6	5	4	3	2	1	0																																										
Not used	T3 activation	T2 activation	T1 activation	Types: 0 – Pt500 1 – Pt1000 2 – 500Π 3 – 1000Π																																													

		Type of flow input 3:
		Bitai
		7 6 5 4 3 2 1 0
22	DTipas3	Not used Units: 0 – m ³ 1 – t Type: 0 – Off 1 – S 2 – E 3 – L
23	Not used	
24	Filtras3	Minimal pulse period of flow input 3 (integer, msec)
		Type of flow input 4:
		Bitai
		7 6 5 4 3 2 1 0
25	DTipas4	Not used Units: 0 – m ³ 1 – t Type: 0 – Off 1 – S 2 – E 3 – L
26	Not used	
27	DTipas4	Minimal pulse period of flow input 4 (integer, msec)
28	DIMP3 ₀	
29	DIMP3 ₁	
30	DIMP3 ₂	
31	DIMP3 ₃	
32	DIMP3 ₀	
33	DIMP4 ₁	
34	DIMP4 ₂	
35	DIMP4 ₃	
36	QMIN1 ₀	
37	QMIN1 ₁	
38	QMIN1 ₂	
39	QMIN1 ₃	
40	QMIN2 ₀	
41	QMIN2 ₁	
42	QMIN2 ₂	
43	QMIN2 ₃	
44	QMIN3 ₀	
45	QMIN3 ₁	
46	QMIN3 ₂	
47	QMIN3 ₃	
48	QMIN4 ₀	
49	QMIN4 ₁	
50	QMIN4 ₂	
51	QMIN4 ₃	
52	QMAX1 ₀	
53	QMAX1 ₁	
54	QMAX1 ₂	
55	QMAX1 ₃	
56	QMAX2 ₀	
57	QMAX2 ₁	
58	QMAX2 ₂	
59	QMAX2 ₃	
60	QMAX3 ₀	
61	QMAX3 ₁	
62	QMAX3 ₂	
63	QMAX3 ₃	
64	QMAX4 ₀	
65	QMAX4 ₁	
66	QMAX4 ₂	
67	QMAX4 ₃	

68	KTEMP ₀	Cold water temperature constant (integer, 0,01 °C)							
69	KTEMP ₁								
70	(T1-T2)min ₀	Min temperature difference T1-T2 (integer, 0,01 °C)							
71	(T1-T2)min ₁								
72	SMIN ₀	Min value of pressure sensors (integer, 0,1 kPa)							
73	SMIN ₁								
74	SMAX ₀	Max value of pressure sensors (integer, 0,1 kPa)							
75	SMAX ₁								
76	SENT ₀	Value of pressure for calculations (integer, 0,1 kPa)							
77	SENT ₁								
78	SIRIB	Limits of current of pressure sensors inputs: 0x00 – 0-20 mA 0x01 – 4-20 mA 0x02 – 0-4 mA							
79	MBusAddr	M-Bus adresas							
80	UARTSpeed1	Boud rate of wire interface		Bits					
81	UARTSpeed2			7	6	5	4	3	2
				0	1	0	1	0	1
82	PPULS1	Parameter for 1 st pulse/frequency output							
83	PPULS2	Parameter for 2 nd pulse/frequency output							
84	PKALBA	Report printing language and interface:							
85	MATVNT	Units:							



			1 - t	1 - t	0x01 - Gcal 0x02 - GJ	
--	--	--	-------	-------	--------------------------	--